

TABLE 1		APPROVED BUILDING SUPPLIER REFERENCE			
UNIT DESCRIPTION	NOMINAL BUILDING SIZE	SUPPLIER 1	SUPPLIER 2	SUPPLIER 3	SUPPLIER 4
13.5kL CDU	10.2m x 3.3m				
13.5kL + 13.5kL CDU	12.2m x 3.3m + (SEPARATE ELEC. BUILDING)				
5kL CDU (MAGNESIUM HYDROXIDE)	10.2m x 3.3m				
3kL + 7kL RCP	10.2m x 3.3m				
7kL + 13.5kL RCP	12.2m x 3.3m				
13.5kL + 13.5kL RCP	12.2m x 3.3m + (SEPARATE ELEC. BUILDING)				

NOTES:

1. FOR GENERAL NOTES REFER TO DRG No. DTC-7002.
2. THERE ARE NO APPROVED BUILDING SUPPLIER DESIGNS FOR THE CDU/RCP BUILDING. A SITE SPECIFIC DESIGN SHALL BE PREPARED FOR EACH CASE AND SUBMITTED TO SYDNEY WATER FOR REVIEW AND APPROVED PRIOR TO FABRICATION. SEE TABLE 1 ON THIS DRAWING.
3. FOUNDATION LEVEL TO BE CONFIRMED WITH SYDNEY WATER IN CONSULTATION WITH THE HUT MANUFACTURER PRIOR TO COMPLETION TO ENSURE THERE IS NO CLASH WITH ACCESS STAIRS OR CONTROL ROOM DOORS.

