



REFERENCE DRAWINGS

DTC-7018 ..... P&ID LINE LEGEND & INSTRUMENTATION SYMBOLS.  
DTC-7019 ..... P&ID PREFIXES AND PIPING CODES.  
DTC-7020 ..... P&ID SYMBOLS LEGEND SHEET.

DOSING POINT NOTES

1. MAGNETIC FLOW METERS TO BE LOCATED A MIN. DISTANCE UPSTREAM AND DOWNSTREAM OF FLOW DISTURBANCES AS INDICATED BY THE VENDOR
2. FLOW TRANSMITTERS INSTALLED ON TRANSFER MAINS USED TO INITIATE CHEMICAL DOSING ON DOSING SYSTEM
3. LEAK DETECTION DEVICE TO BE INSTALLED AT LOW POINT/S ON DOSING PIPE AND INSTALLED INSIDE ACCESSIBLE PIT LOCAL TO DOSING POINT. DRAIN PIPE FROM PIT TO BE FITTED WITH FLAP VALVE (OR SIMILAR) TO PREVENT ODOUR ENTERING THE PIT. LEAK DETECTION METHOD INDICATED IN DRAWING IN DRAWING IS ONE OPTION ONLY. OTHER OPTIONS CAN BE PERMITTED IF APPROVED BY THE PRINCIPAL.
4. PIT TO BE WATER TIGHT WITH LIGHTWEIGHT COVER.
5. FOR GENERAL NOTES REFER DRG. No. DTC-7002.
6. FEASIBILITY TO BE DETERMINED ON A PROJECT BY PROJECT LEVEL BASED ON RL's OF SUMP AND DOSING PIT.

THIS DRAWING MAY ONLY BE USED IN THE COURSE OF AND FOR THE PURPOSE OF CREATING SYDNEY WATER ASSETS. USE THIS DRAWING WITH CARE. YOU ARE RESPONSIBLE TO APPLY THE WORK SHOWN IN THIS DRAWING CORRECTLY IN THE CIRCUMSTANCES OF YOUR PROJECT. YOU MUST ENSURE THE WORK IS FIT FOR PURPOSE AND WILL PERFORM ITS INTENDED FUNCTION AS REQUIRED.



Sydney  
**WATER**

©COPYRIGHT  
STATE OF NEW SOUTH WALES THROUGH SYDNEY  
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED MAR 2017

KEN WIGGINS  
MANAGER, E & ES

ENGINEERING & ENVIRONMENTAL SERVICES

A

ORIGINAL ISSUE

LETTER

DETAILS OF AMENDMENT

KW

17/03/17

APP'D

DATE

DEEMED TO COMPLY DRAWINGS

TYPICAL RECHLORINATION PLANT  
SODIUM HYPOCHLORITE  
P&ID - DOSING POINTS

DTC  
7015