

# Cronulla Wastewater Treatment Plant

## June Pollution Monitoring Summary



### EPL 1728

Summary period: 01-06-2022 to 30-06-2022

Date obtained: 07-07-2022

Date published: 15-07-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	3	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	13
biochemical oxygen demand	mg/L	every 6 days	5	<2	3	6
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	3.7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	23.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	4
zinc	ug/L	monthly	1	-	-	20

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	4	11
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	68.4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## May Pollution Monitoring Summary



### EPL 1728

Summary period: 01-05-2022 to 31-05-2022

Date obtained: 09-06-2022

Date published: 17-06-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
biochemical oxygen demand	mg/L	every 6 days	5	<2	2.4	7
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	3
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	19.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	4	9
zinc	ug/L	monthly	1	-	-	22

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	4	13861	69,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## April Pollution Monitoring Summary



### EPL 1728

Summary period: 01-04-2022 to 30-04-2022

Date obtained: 09-05-2022

Date published: 20-05-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	4	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	4	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	5	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	18
biochemical oxygen demand	mg/L	every 6 days	5	<2	4.4	17
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	4	15
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.3
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	13.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	5	18
zinc	ug/L	monthly	1	-	-	19

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	5	103	250
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	79.3

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## March Pollution Monitoring Summary



### EPL 1728

Summary period: 01-03-2022 to 31-03-2022

Date obtained: 06-04-2022

Date published: 15-04-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	25	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	21	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	35	no <sup>1</sup>

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

<sup>1</sup> Under Environment Protection Licence 1728 conditions, as set by the NSW Environment Protection Authority, exceedance of 3DGM concentration limit is permitted when a wet weather bypass is the sole cause of exceedance. Wet weather in 1-10 March resulted in the plant operating under wet weather requirements.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	220
biochemical oxygen demand	mg/L	every 6 days	5	<2	11.2	28
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	8	21
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	20.7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	4
nonylphenol ethoxylate	ug/L	monthly	1	-	-	6
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	17	54
zinc	ug/L	monthly	1	-	-	40

  

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	17424	79,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	51.4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## February Pollution Monitoring Summary



### EPL 1728

Summary period: 01-02-2022 to 28-02-2022

Date obtained: 12-03-2022

Date published: 24-03-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	17
biochemical oxygen demand	mg/L	every 6 days	5	<2	5.4	25
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	4	19
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	7
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	5.8
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	6	30
zinc	ug/L	monthly	1	-	-	28

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	1009	4,600
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	51.1

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## January Pollution Monitoring Summary



### EPL 1728

Summary period: 01-01-2022 to 31-01-2022

Date obtained: 08-02-2022

Date published: 11-02-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	3	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	3	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	25
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.3
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	8.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	25

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	20	91
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	49.7

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## December Pollution Monitoring Summary



### EPL 1728

Summary period: 01-12-2021 to 31-12-2021

Date obtained: 07-01-2022

Date published: 20-01-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	8	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	3	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	26
biochemical oxygen demand	mg/L	every 6 days	5	2	4.6	8
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	3
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	6.6
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	17.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	3
zinc	ug/L	monthly	1	-	-	20

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	2	2057	9,300
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	54

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).



# Cronulla Wastewater Treatment Plant

## November Pollution Monitoring Summary



### EPL 1728

Summary period: 01-11-2021 to 30-11-2021

Date obtained: 10-12-2021

Date published: 17-12-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	4	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	26
biochemical oxygen demand	mg/L	every 6 days	5	3	4.2	6
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	3.5
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	18.1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	20

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	2	2365	8,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	72.3

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).



# Cronulla Wastewater Treatment Plant

## October Pollution Monitoring Summary



### EPL 1728

Summary period: 01-10-2021 to 31-10-2021

Date obtained: 08-11-2021

Date published: 12-11-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	3	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	27
biochemical oxygen demand	mg/L	every 6 days	5	3	4.6	8
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	7.1
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	12.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	28

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	6	21	96	320
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	89

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## September Pollution Monitoring Summary



### EPL 1728

Summary period: 01-09-2021 to 30-09-2021

Date obtained: 07-10-2021

Date published: 13-10-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	6	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	28
biochemical oxygen demand	mg/L	every 6 days	5	4	5.8	7
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	4.9
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	21.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	20

  

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	5	19	40
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## August Pollution Monitoring Summary



### EPL 1728

Summary period: 01-08-2021 to 31-08-2021

Date obtained: 09-09-2021

Date published: 22-09-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	9	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	27
biochemical oxygen demand	mg/L	every 6 days	6	6	8.67	13
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	3
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	6
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	19.4
nonylphenol ethoxylate	ug/L	monthly	1	-	-	9
oil and grease	mg/L	every 6 days	6	<5	<5	<5
total suspended solids	mg/L	every 6 days	6	<2	<2	6
zinc	ug/L	monthly	1	-	-	26

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	53	180
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	49.2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Cronulla Wastewater Treatment Plant

## July Pollution Monitoring Summary



### EPL 1728

Summary period: 01-07-2021 to 31-07-2021

Date obtained: 04-08-2021

Date published: 18-08-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	40	6	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	40	<2	yes
oil and grease	mg/L	monthly	15	<5	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	24
biochemical oxygen demand	mg/L	every 6 days	5	5	6.2	8
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	5.9
cyanide	ug/L	monthly	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	21.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
oil and grease	mg/L	every 6 days	5	<5	<5	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	29

EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	2	21	58
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 17 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).