

# Liverpool Water Resource Recovery Facility

## April Pollution Monitoring Summary



### EPL 372

Summary period: 01-04-2024 to 30-04-2024  
 Date obtained: 01-05-2024  
 Date published: 13-05-2024

**Licensee:** Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	52	yes
total suspended solids	mg/L	on bypass	100	24	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	5	10	28.6	52
faecal coliforms	CFU/100mL	on bypass	5	1,200,000	3700000	6,000,000
total suspended solids	mg/L	on bypass	5	14	18	24

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

# Liverpool Water Resource Recovery Facility

## April Pollution Monitoring Summary



### EPL 372

Summary period: 01-04-2024 to 30-04-2024

Date obtained: 01-05-2024

Date published: 13-05-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	42	yes
total suspended solids	mg/L	on bypass	100	150	no <sup>1</sup>

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	2	21	31.5	42
faecal coliforms	CFU/100mL	on bypass	2	140,000	530000	920,000
total suspended solids	mg/L	on bypass	2	27	89	150

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81.

<sup>1</sup> Total suspended solids exceedance on 6 April. Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather. Wet weather from 5 to 6 April resulted in plant operating under Environmental Protection Licence wet weather requirements.

# Liverpool Water Resource Recovery Facility

## March Pollution Monitoring Summary



### EPL 372

Summary period: 01-03-2024 to 31-03-2024

Date obtained: 01-04-2024

Date published: 11-04-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	11	yes
total suspended solids	mg/L	on bypass	100	14	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	1	-	-	11
faecal coliforms	CFU/100mL	on bypass	1	-	-	410,000
total suspended solids	mg/L	on bypass	1	-	-	14

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	9	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	9

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the March monitoring period.

# Liverpool Water Resource Recovery Facility

## February Pollution Monitoring Summary



### EPL 372

Summary period: 01-02-2024 to 29-02-2024

Date obtained: 04-03-2024

Date published: 15-03-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	44	yes
total suspended solids	mg/L	on bypass	100	30	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	7	13	28.71	44
faecal coliforms	CFU/100mL	on bypass	7	100,000	1442857	4,400,000
total suspended solids	mg/L	on bypass	7	22	24	30

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	8	yes
total suspended solids	mg/L	monthly during discharge	100	5	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	8
total suspended solids	mg/L	monthly during discharge	1	-	-	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

# Liverpool Water Resource Recovery Facility February Pollution Monitoring Summary



## EPL 372

Summary period: 01-02-2024 to 29-02-2024

Date obtained: 04-03-2024

Date published: 15-03-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	41	yes
total suspended solids	mg/L	on bypass	100	32	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	1	-	-	41
faecal coliforms	CFU/100mL	on bypass	1	-	-	3,000,000
total suspended solids	mg/L	on bypass	1	-	-	32

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81.

# Liverpool Water Resource Recovery Facility

## January Pollution Monitoring Summary

### EPL 372



Summary period: 01-01-2024 to 31-01-2024

Date obtained: 01-02-2024

Date published: 15-02-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	40	yes
total suspended solids	mg/L	on bypass	100	35	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	3	11	29.67	40
faecal coliforms	CFU/100mL	on bypass	3	37,000	2112333	4,000,000
total suspended solids	mg/L	on bypass	3	12	23	35

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	<2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	<2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the January monitoring period.

# Liverpool Water Resource Recovery Facility

## December Pollution Monitoring Summary

### EPL 372



Summary period: 01-12-2023 to 31-12-2023

Date obtained: 11-01-2024

Date published: 22-01-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	51	yes
total suspended solids	mg/L	on bypass	100	90	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	7	8	27.43	51
faecal coliforms	CFU/100mL	on bypass	7	13	1773288	6,000,000
total suspended solids	mg/L	on bypass	7	9	28	90

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	<2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	<2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the December monitoring period.

# Liverpool Water Resource Recovery Facility

## November Pollution Monitoring Summary



### EPL 372

Summary period: 01-11-2023 to 30-11-2023

Date obtained: 13-12-2023

Date published: 19-12-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	39	yes
total suspended solids	mg/L	on bypass	100	57	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	5	11	23.4	39
faecal coliforms	CFU/100mL	on bypass	5	520,000	2204000	4,800,000
total suspended solids	mg/L	on bypass	5	4	22	57

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	3	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	3

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the November monitoring period.



# Liverpool Water Resource Recovery Facility

## October Pollution Monitoring Summary



### EPL 372

Summary period: 01-10-2023 to 31-10-2023

Date obtained: 01-11-2023

Date published: 15-11-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	6	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15. There was no discharge from EPA ID 15 during the October monitoring period.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the October monitoring period.

# Liverpool Water Resource Recovery Facility September Pollution Monitoring Summary



## EPL 372

Summary period: 01-09-2023 to 30-09-2023

Date obtained: 05-10-2023

Date published: 13-10-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	17	yes
total suspended solids	mg/L	on bypass	100	54	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	2	15	16	17
faecal coliforms	CFU/100mL	on bypass	2	92,000	136,000	180,000
total suspended solids	mg/L	on bypass	2	19	37	54

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	3	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	3

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the September monitoring period.

# Liverpool Water Resource Recovery Facility

## August Pollution Monitoring Summary



### EPL 372

Summary period: 01-08-2023 to 31-08-2023

Date obtained: 05-09-2023

Date published: 14-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	34	yes
total suspended solids	mg/L	on bypass	100	27	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	2	31	32.5	34
faecal coliforms	CFU/100mL	on bypass	2	260,000	1230000	2,200,000
total suspended solids	mg/L	on bypass	2	22	25	27

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	<2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	<2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the August monitoring period.

# Liverpool Water Resource Recovery Facility

## July Pollution Monitoring Summary

### EPL 372



Summary period: 01-07-2023 to 31-07-2023

Date obtained: 01-08-2023

Date published: 15-08-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	8	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

**Table 2: Routine monitoring data**

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	8

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 372, collection of samples is required from LP0015 after 3 hours of continuous discharge from EPA Point 15. There was no discharge from EPA ID 15 during the July monitoring period.

As per clause M2.4 under EPL 372, collection of samples is required from LP0081 after 3 hours of continuous discharge from EPA Point 81. There was no discharge from EPA ID 81 during the July monitoring period.