

# Wollongong Wastewater Treatment Plant

## 2019-20 Pollution monitoring yearly limit summaries



### EPL 218

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	41	20	<2	yes
total suspended solids	mg/L	every 6 days	61	<2	51	30	<2	yes

90 percentile yearly summary								
EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	11	110	430	50	yes
copper	ug/L	monthly	12	2.9	37.8	150	34	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	1.1	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	2,000	<30	yes
total suspended solids	mg/L	every 6 days	61	<2	51	40	7	yes

# Wollongong Wastewater Treatment Plant

## 2019-20 Pollution monitoring yearly limit summaries



### EPL 218

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	11	110	120	27	yes
copper	ug/L	monthly	12	2.9	37.8	86	16	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.6	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	250	<30	yes

EPA Point 5 Site code WO0005		Point description: At the inlet to the effluent pumping station				
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
chlorine (total residual)	mg/L	on bypass <sup>1</sup>	1	-	-	<0.04

<sup>1</sup>Special Frequency 2 means the collection of samples every six (6) days following a bypass or failure of the primary disinfection process, until results are below the detection limit.