


THIS DRAWING MAY ONLY BE USED IN THE COURSE OF AND FOR THE PURPOSE OF CREATING SYDNEY WATER ASSETS. USE THIS DRAWING WITH CARE. THE USER IS RESPONSIBLE FOR THE CORRECT APPLICATION OF THIS DRAWING. THE USE OF DTC DRAWINGS IS SUBJECT TO TERMS AND CONDITIONS AS PUBLISHED BY SYDNEY WATER.

NOTES

1. SITE STRUCTURES, PIPEWORK AND CONDUITS SHOWN INDICATIVE ONLY. LAYOUT IS TO BE DESIGNED FOR EACH SITE SPECIFIC APPLICATION AND DETAILED ON A SITE SPECIFIC PLAN.
2. FOR FURTHER DETAILS OF PUMP STATION REFER DRAWING NO. DTC/6011 - DTC/6013.
3. WATER TO DRAIN AWAY FROM STRUCTURES AND ELECTRICAL PITS.
4. THE PROPERTY BOUNDARY SHALL ENCOMPASS ANY EARTHWORKS REQUIRED TO DELIVER THE PUMPING STATION. IN THE CASE OF A CUTTING, THE PROPERTY BOUNDARY SHALL BE LOCATED AT LEAST 1500mm BEYOND THE TOP OF THE CUT. IN THE CASE OF THE EMBANKMENT, THE BOUNDARY SHALL BE LOCATED 1500mm BEYOND THE TOE OF THE EMBANKMENT.
5. THE SITE FENCE SHALL BE LOCATED AT THE PROPERTY BOUNDARY. WHERE THE NEIGHBOURING LAND USE IS OPEN SPACE / RECREATION, AND SUBJECT TO THE RELEVANT LOCAL GOVERNMENT AUTHORITY, THE FENCE MAY BE LOCATED AT THE TOP OF EMBANKMENTS ENHANCING THE AESTHETIC VALUE OF THE OPEN SPACE. OWNERSHIP AND EASEMENT CONDITIONS OF BATTER SLOPES BEYOND THE FENCE LINE MUST BE CONFIRMED WITH SYDNEY WATER & SHALL BE BASED ON PROJECT SPECIFIC REQUIREMENTS.
6. SITE STORMWATER OUTLET TO EITHER PUBLIC STORMWATER DRAINAGE SYSTEM OR PIPED TO WATERWAY/CREEK.
7. SITE SPECIFIC DESIGN TO NOMINATE CONSTRUCTION JOIN, SAW CUT, TOOLED AND ISOLATION JOINT LOCATIONS.

LEGEND:

- 40mm SINGLE SIZE GRAVEL  
150 DEEP WITH WEED MAT UNDER
- HARDSTAND AREA
- LANDSCAPE TREES/SHRUBS
- GREEN = TRUCK FORWARD TURNING PATH  
RED = TRUCK REVERSE TURNING PATH



EXAMPLE SITE LAYOUT 1 - SITE PLAN

SCALE 1:125

Sydney  
**WATER**

©COPYRIGHT  
STATE OF NEW SOUTH WALES THROUGH SYDNEY  
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED

NORBERT SCHAEFER  
MANAGER - ENGINEERING

ENGINEERING & TECHNICAL SUPPORT

B  
A  
LETTER

GENERAL UPDATE (PREVIOUSLY DRAWING DTC/6003)  
ORIGINAL ISSUE  
DETAILS OF ISSUE / AMENDMENT

NS  
KW  
APP'D DATE

25/06/21  
22/06/15

DEEMED TO COMPLY DRAWINGS

SEWAGE PUMPING STATION  
EXAMPLE SITE LAYOUT 1  
SITE PLAN

DTC

6003

ISSUE  
B

DATE  
25/06/21