


LEGEND

RRJ _____ RUBBER RING JOINT
 SCJ _____ SOLVENT CEMENT JOINT

PLAN

SCALE - 1:10



SECTION A - A

SCALE - 1:10

NOTES

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SEWERAGE CODE OF AUSTRALIA WSA 02 - 2002 - 2.2 SYDNEY WATER EDITION 1 - VERSION 3 - PART 3.
2. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
3. ALL PIPEWORK SHALL COMPLY WITH REQUIREMENTS OF AS/NZS 1260:2009 PVC U PIPES AND FITTINGS FOR DRAIN, WASTE AND VENT APPLICATION. RETICULATION SEWER PIPEWORK SHALL BE CLASS SN8. PROPERTY CONNECTION SEWER PIPEWORK SHALL BE CLASS SN10. SOLVENT CEMENTS & PRIMING FLUIDS SHALL COMPLY WITH THE REQUIREMENTS OF AS1379.
4. EMBEDMENT MATERIAL SHALL BE EITHER:
 a. SINGLE SIZE AGGREGATE TO WSA PS - 351 - NOMINAL SIZE 7 OR 10mm
 b. GRADED AGGREGATE TO WSA PS - 351 - NOMINAL SIZE 10mm
5. MINIMUM LAP AT ALL JOINTS IN GEOTEXTILE FABRIC SHALL BE 300MM. A GEOTEXTILE OVERLAY MAY BE USED IN LIEU OF A GEOTEXTILE SURROUND WHERE THE NATIVE SOIL IS NON-DISPERSIVE VERY STIFF OR HARD CLAY, OR ROCK. THE OVERLAY SHALL BE PLACED DIRECTLY OVER THE EMBEDMENT AND EXTEND THE FULL WIDTH OF THE TRENCH.
6. TAPE MESSAGE SHALL BE "CAUTION - SEWER BURIED BELOW". TAPE TO EXTEND 300 BEYOND GROUND LEVEL
7. THE MINIMUM LENGTH OF RISER PIPE SHALL BE 250mm. DEPTH TO PROPERTY CONNECTION POINT (PCP) MAY BE REDUCED FOR SHALLOW INSTALLATIONS TO PROVIDE THE MINIMUM LENGTH OF RISER PIPE.
8. THE USE OF STANDARD DESIGNS MAY INTRODUCE UNINTENDED SAFETY RISKS FOR SITE SPECIFIC APPLICATION. THE USER SHALL ADDRESS SAFETY RISKS THROUGH SITE SPECIFIC ASSESSMENT.
9. THE USER SHALL BE RESPONSIBLE FOR DESIGN OF ANY TEMPORARY WORKS.



APPROVED

 KEN WIGGINS
 MANAGER E & ES

A	ORIGINAL ISSUE	K.W.	18.03.15
LETTER	DETAILS OF ISSUE / AMENDMENT	APP'D	DATE

DEEMED TO COMPLY DRAWINGS
**DN100 PVC-U
 PROPERTY CONNECTION SEWER
 FOR SINGLE PROPERTY**

DTC
2120

© COPYRIGHT
 STATE OF NEW SOUTH WALES THROUGH SYDNEY
 WATER CORPORATION. ALL RIGHTS RESERVED

ENGINEERING & ENVIRONMENTAL SERVICES

A	ORIGINAL ISSUE	K.W.	18.03.15
LETTER	DETAILS OF ISSUE / AMENDMENT	APP'D	DATE

DEEMED TO COMPLY DRAWINGS
**DN100 PVC-U
 PROPERTY CONNECTION SEWER
 FOR SINGLE PROPERTY**

ISSUE	DATE
A	18/03/15