

## Concentration Limit Table

### Liverpool Wastewater Treatment Plant

#### EPL 372

Updated 10-08-2023

Sydney Water's treatment plants operate under environmental protection licences issued by the NSW Environmental Protection Authority (EPA). For each monitoring/discharge point the concentration of a pollutant must not exceed the concentration limits specified for that pollutant in the table.

pollutant	unit of measure	100 percentile limit
biochemical oxygen demand	mg/L	100
total suspended solids	mg/L	100

A licence condition with a 100 Percentile Limit means that 100% of samples (or all samples) taken must not exceed the limit for that pollutant.