

Concentration Limit Table

North Richmond Water Filtration Plant

EPL 5425

Sydney Water's filtration plants operate under environmental protection licences issued by the NSW Environmental Protection Authority (EPA). For each monitoring/discharge point the concentration of a pollutant must not exceed the concentration limits specified for that pollutant in the table.

pollutant	unit of measure	100 percentile limit
pH	pH units	6.5 - 8.5
total suspended solids	mg/L	30

A licence condition with a 100 Percentile Limit means that 100% of samples (or all samples) taken must not exceed the limit for that pollutant.