


- NOTES:**
1. GAS CHECK MAINTENANCE HOLE MUST ALWAYS REMAIN WITHIN SITE FENCE BOUNDARY
  2. \* SUBJECT TO HYDRAULIC ASSESSMENT.
  3. PROVIDE BROOM FINISH AND SLOP FLOOR AT 1:8 IN ALL DIRECTIONS TO OUTLET.
  4. BASE SLAB CAN BE A CIRCULAR BASE SLAB IF CAISSON OR SIMILAR METHOD USED. DESIGN ENGINEER TO DESIGN FOR BUOYANCY FORCES AND GROUND CONDITIONS.



INLET MH SIZE (DN) *	GAS CHECK MH OUTLET PIPE SIZE (DN)
150–250	300
300	375
375	450
450	525
500	600

**GAS CHECK MAINTENANCE HOLE STRUCTURE - PLAN**  
SCALE 1: 20

NORBERT SCHAEFER  
MANAGER – ENGINEERING

## ENGINEERING & TECHNICAL SUPPORT

B	GENERAL UPDATE (PREVIOUSLY DRAWING DTC/6008)	N.S.	25/06/21
A	ORIGINAL ISSUE	KW	22/06/15
LETTER	DETAILS OF ISSUE / AMENDMENT	APP'D	DATE

## DEEMED TO COMPLY DRAWINGS

SEWAGE PUMPING STATION  
GAS CHECK MAINTENANCE HOLE - DN1800  
GENERAL ARRANGEMENT

DTC

6017

ISSUE	DATE
B	25/06/21