


- 
- Technical drawings of the valve assembly showing top and side views with dimensions and labels.
- Top View Dimensions:**
- Overall width: 110
  - Distance between anchor holes: 80
  - Anchor hole diameter: 50
- Labels for Top View:**
- PROVIDE 2-M6 SS316 ANCHORS INTO CONCRETE WALL
- Side View Dimensions and Labels:**
- Valve chamber concrete wall thickness: 50
  - NRV swing arm and counter weight: 3 PL.
  - M10x50 LG. THREADED ROD WELDED TO BASE PLATE (CENTRAL)
  - VALVE CHAMBER CONCRETE WALL
  - NRV SWING ARM AND COUNTER WEIGHT

DETAIL SCALE 1:2

ALL MATERIAL GRADE 316  
STAINLESS STEEL.  
3 REQUIRED.  
(ONE FOR EACH PUMP DISCHARGE  
LINE NRV'S AND BYPASS NRV)



© COPYRIGHT  
STATE OF NEW SOUTH WALES THROUGH SYDNEY  
WATER CORPORATION. ALL RIGHTS RESERVED

NORBERT SCHAEFER  
MANAGER - ENGINEERING

B	GENERAL UPDATE (PREVIOUSLY DRAWING DTC/6006)
A	ORIGINAL ISSUE
LETTER	DETAILS OF ISSUE / AMENDMENT

# SEWAGE PUMPING STATION VALVE CHAMBER GENERAL ARRANGEMENT

6014

ISSUE	DATE
B	25/06/21