


COMMS/ELEC CONDUIT

- A TYPE A 4 x 50mm HDUG 24V (PRV TO CONTROL PANEL)
- B TYPE B 1 X 50mm HDUG 24V (FLOAT SWITCH TO CONTROL PANEL)
- C TYPE C 1 x 50mm HDUG 24V (FLOWMETER TO CONTROL PANEL)
- D TYPE D 1 x 50mm HDUG 240V (CONTROL PANEL TO POWER POLE)
- E TYPE E 1 x 50mm WHITE COMMUNICATIONS TELSTRA LEAD IN CONDUIT
- F TYPE F 1 x 32mm HDUG (CONTROL PANEL TO EARTH PIT)
- G TYPE G 1 X 50mm HDUG 240V (SUMP PUMP TO CONTROL PANEL)
- H TYPE H 1 x 50mm HDUG (SPARE CONDUIT) CAPPED 1m FROM PLINTH

- NOTES:
- 1. ALL ELECTRICAL COMPONENTS MUST MEET THE REQUIREMENT OF SWC TECHNICAL SPECIFICATION - ELECTRICAL.
 - 2. INSTALL A WARNING LABEL STATING "SUMP PUMP TO BE SINGLE PHASE 240V, NO GREATER THAN 250 WATTS" NEAR THE GENERAL POWER OUTLET IN THE CONTROL PANEL.

TABLE 1			
LOCATION OF INSTALLED ITEMS			
DESCRIPTION	EASTING M.G.A.	NORTHING M.G.A.	RL m (AHD)
SURVEY MARK ON PRV CHAMBER			
FLOWMETER (AT SURFACE LEVEL)			
PRESSURE GAUGE (LEVEL)			
CENTRE OF CONTROL PANEL SLAB			
POWER POLE			
DATE OF SURVEY			



PRESSURE REDUCING VALVE & CONDUIT ARRANGEMENT
SCALE : NTS

FOR NOTES & REFERENCE DRAWINGS SEE
DRAWING No. DTC-6400

THIS DRAWING IS NOT FOR CONSTRUCTION
ARRANGEMENT IS INDICATIVE ONLY. THE
DESIGNER IS TO SPECIFY THE LOCATION
DETAILS OF PIPEWORK & CONDUITS