

Name of water treatment plant	Woronora Water Filtration Plant
--------------------------------------	---------------------------------

System Summary	Projected					
	2026	2031	2036	2041	2046	2056
Total Equivalent Population (EP)	37,869	39,931	40,651	41,370	41,905	42,978
Average day demand (ADD) ML/d	25	26	26	27	27	28
Max day demand (MDD) ML/d	48	50	51	52	53	54

Current treatment capacity	(ML/d)
Treatment / filtration - normal raw water quality	147
Treatment / filtration - poor raw water quality	120

Treatment capacity constraints for 2020 – 2056	Estimated year of exceedance
No identified capacity constraints.	N/A

Anticipated augmentation and upgrades			
Year commissioned	Description	Approximate capital cost (\$M)	Impact on servicing capacity
N/A	None identified		

Further investigations
No capacity investigations underway.