

**Bondi Wastewater Treatment Plant  
2020-21 Air quality pollution monitoring summary**



**EPL 1688**

Summary period: 01-07-2020 to 30-06-2021  
Date published : 16-08-2020

**Licensee:** Sydney Water  
PO Box 399  
PARRAMATTA NSW 2124

**Table 1: Routine monitoring data**

| EPA Point 11    | Point description: Air sampling outlet of cogeneration facility |                    |                   |                |             |                |
|-----------------|---|--------------------|-------------------|----------------|-------------|----------------|
| pollutant       | unit of measure   | sampling frequency | number of samples | minimum result | mean result | maximum result |
| nitrogen oxides | mg/m <sup>3</sup>   | yearly             | 3                 | 345            | 406         | 449            |

Yearly measurement was taken on 24-11-2020.