

West Hornsby Wastewater Treatment Plant

June Pollution Monitoring Summary



EPL 1695

Summary period: 01-06-2021 to 30-06-2021

Date obtained: 09-07-2021

Date published: 20-07-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	135
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	6.1
faecal coliforms	CFU/100mL	every 6 days	5	5	15	40
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	42
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.03
nitrogen (total)	mg/L	every 6 days	5	5.18	9.83	23.2
phosphorus (total)	mg/L	every 6 days	5	0.05	0.24	0.87
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	15

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the reporting monitoring period.

West Hornsby Wastewater Treatment Plant

May Pollution Monitoring Summary



EPL 1695

Summary period: 01-05-2021 to 31-05-2021

Date obtained: 08-06-2021

Date published: 21-06-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	183
biochemical oxygen demand	mg/L	every 6 days	5	<2	2	10
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	9
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	6.9
faecal coliforms	CFU/100mL	every 6 days	6	5	865	5,100
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	94
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.87	4.26
nitrogen (total)	mg/L	every 6 days	5	4.83	6.2	8.69
phosphorus (total)	mg/L	every 6 days	5	0.04	0.22	0.56
total suspended solids	mg/L	every 6 days	5	<2	2	11
zinc	ug/L	monthly	1	-	-	16

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the May monitoring period.

West Hornsby Wastewater Treatment Plant

April Pollution Monitoring Summary



EPL 1695

Summary period: 01-04-2021 to 30-04-2021

Date obtained: 08-05-2021

Date published: 17-05-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	167
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	5.2
faecal coliforms	CFU/100mL	every 6 days	5	6	13	20
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	34
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.04	0.14
nitrogen (total)	mg/L	every 6 days	5	4.26	4.53	4.84
phosphorus (total)	mg/L	every 6 days	5	0.03	0.03	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	14

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the April monitoring period.

West Hornsby Wastewater Treatment Plant

March Pollution Monitoring Summary



EPL 1695

Summary period: 01-03-2021 to 31-03-2021

Date obtained: 14-04-2021

Date published: 23-04-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	16	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	15	yes
total suspended solids	mg/L	monthly	10	31	¹ no

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	762
biochemical oxygen demand	mg/L	every 6 days	6	<2	3.67	17
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	4	16
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	22.7
faecal coliforms	CFU/100mL	every 6 days	5	18	20033	100,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	878
nitrogen (ammonia)	mg/L	every 6 days	6	0.01	1.21	5.11
nitrogen (total)	mg/L	every 6 days	6	2.56	5.53	10.4
phosphorus (total)	mg/L	every 6 days	6	0.03	0.26	0.98
total suspended solids	mg/L	every 6 days	6	<2	6	27
zinc	ug/L	monthly	1	-	-	31

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the March monitoring period.

¹Under condition L3.5 in the Environment Protection Licence 2269, as set by the NSW Environment Protection Authority, when a wet weather bypass flow is occurring, exceedances of the 3DGM concentration limit in condition L3.4 are permitted at point 4 for the duration of the bypass where the bypass was the sole cause of the exceedance. Wet weather flows between 19-22 March was the sole cause of the 3DGM exceedance.

West Hornsby Wastewater Treatment Plant

February Pollution Monitoring Summary



EPL 1695

Summary period: 01-02-2021 to 28-02-2021

Date obtained: 03-03-2021

Date published: 12-03-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	198
biochemical oxygen demand	mg/L	every 6 days	4	<2	<2	<2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	4	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	3.7
faecal coliforms	CFU/100mL	every 6 days	4	16	26	32
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	37
nitrogen (ammonia)	mg/L	every 6 days	4	0.01	0.01	0.01
nitrogen (total)	mg/L	every 6 days	4	2.73	3.91	4.86
phosphorus (total)	mg/L	every 6 days	4	0.02	0.03	0.03
total suspended solids	mg/L	every 6 days	4	<2	<2	<2
zinc	ug/L	monthly	1	-	-	12

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the February monitoring period.

West Hornsby Wastewater Treatment Plant

January Pollution Monitoring Summary



EPL 1695

Summary period: 01-01-2021 to 31-01-2021

Date obtained: 14-02-2021

Date published: 23-02-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	183
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	7
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	7
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	5
cyanide	ug/L	bi-annually	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	6	23	51	79
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	44
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.61	2.98
nitrogen (total)	mg/L	every 6 days	5	3.74	5	6.52
phosphorus (total)	mg/L	every 6 days	5	0.03	0.11	0.42
total suspended solids	mg/L	every 6 days	5	<2	3	12
zinc	ug/L	monthly	1	-	-	12

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the January monitoring period.

West Hornsby Wastewater Treatment Plant

December Pollution Monitoring Summary



EPL 1695

Summary period: 01-12-2020 to 31-12-2020

Date obtained: 12-01-2021

Date published: 18-01-2021

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	97
biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	5.3
faecal coliforms	CFU/100mL	every 6 days	5	7	30	60
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	28
nitrogen (ammonia)	mg/L	every 6 days	6	0.02	0.02	0.03
nitrogen (total)	mg/L	every 6 days	6	4.17	5.63	7.06
phosphorus (total)	mg/L	every 6 days	6	0.05	0.17	0.49
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	13

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the December monitoring period.

West Hornsby Wastewater Treatment Plant

November Pollution Monitoring Summary



EPL 1695

Summary period: 01-11-2020 to 30-11-2020

Date obtained: 15-12-2020

Date published: 17-12-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	203
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	3.7
faecal coliforms	CFU/100mL	every 6 days	5	19	29	45
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	42
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.08	0.22
nitrogen (total)	mg/L	every 6 days	5	2.72	3.8	4.82
phosphorus (total)	mg/L	every 6 days	5	0.04	0.05	0.06
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	15

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the November monitoring period.

West Hornsby Wastewater Treatment Plant

October Pollution Monitoring Summary



EPL 1695

Summary period: 01-10-2020 to 31-10-2020

Date obtained: 05-11-2020

Date published: 13-11-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	226
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	9
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	7
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.9
faecal coliforms	CFU/100mL	every 6 days	5	14	591	2,800
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	55
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	1.47	6.34
nitrogen (total)	mg/L	every 6 days	5	3.71	5.88	11.7
phosphorus (total)	mg/L	every 6 days	5	0.05	0.25	1.02
total suspended solids	mg/L	every 6 days	5	<2	8	40
zinc	ug/L	monthly	1	-	-	14

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the October monitoring period.

West Hornsby Wastewater Treatment Plant

September Pollution Monitoring Summary



EPL 1695

Summary period: 01-09-2020 to 30-09-2020

Date obtained: 15-10-2020

Date published: 23-10-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	133
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	3.6
faecal coliforms	CFU/100mL	every 6 days	5	32	63	110
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	66
nitrogen (ammonia)	mg/L	every 6 days	5	0.14	0.54	1.27
nitrogen (total)	mg/L	every 6 days	5	3.38	4.51	6.23
phosphorus (total)	mg/L	every 6 days	5	0.06	0.07	0.09
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	13

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the September monitoring period.

Note: biochemical oxygen demand monitoring commenced from September 2020.

West Hornsby Wastewater Treatment Plant

August Pollution Monitoring Summary



EPL 1695

Summary period: 01-08-2020 to 31-08-2020

Date obtained: 05-09-2020

Date published: 16-09-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	191
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	4	12
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	1.6
faecal coliforms	CFU/100mL	every 6 days	5	18	2280	11,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	56
nitrogen (ammonia)	mg/L	every 6 days	5	0.64	3.05	7.86
nitrogen (total)	mg/L	every 6 days	5	2.69	5.48	9.7
phosphorus (total)	mg/L	every 6 days	5	0.04	0.36	1.09
total suspended solids	mg/L	every 6 days	5	<2	10	38
zinc	ug/L	monthly	1	-	-	12

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the August monitoring period.

West Hornsby Wastewater Treatment Plant

July Pollution Monitoring Summary



EPL 1695

Summary period: 01-07-2020 to 31-07-2020

Date obtained: 06-08-2020

Date published: 14-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WH0005		Point description: Downstream of the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	230
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	2	11
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
copper	ug/L	monthly	1	-	-	2.7
cyanide	ug/L	monthly	1	-	-	<5
faecal coliforms	CFU/100mL	every 6 days	5	22	184	740
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	54
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.45	2.03
nitrogen (total)	mg/L	every 6 days	5	1.28	2.92	4.7
phosphorus (total)	mg/L	every 6 days	5	0.04	0.13	0.49
total suspended solids	mg/L	every 6 days	5	<2	3	14
zinc	ug/L	monthly	1	-	-	16

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

As per clause M2.4 under EPL 1695, collection of daily samples from EPA Points 7 or 10 is required during the occurrence of any bypass or discharge from EPA Point 8 or 9, greater than 2 hours during normal working hours. There was no bypass recorded from EPA Point 8 or 9 during normal working hours greater than 2 hours in the July monitoring period.