

North Head Wastewater Treatment Plant

2022-23 Pollution monitoring yearly limit summaries



EPL 378

Summary period: 01-07-2022 to 30-06-2023

Date published: 1-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

| 50 percentile yearly summary | | | | | | | | |
|---------------------------------|-----------------|--|-------------------|----------------|----------------|---------------------|---------------------|---------------|
| EPA Point 8 Site code NH0008 | | Point description: In effluent channel downstream of the dropshaft | | | | | | |
| pollutant | unit of measure | sampling frequency | number of samples | minimum result | maximum result | 50 percentile limit | 50 percentile value | within limits |
| oil and grease | mg/L | every 6 days | 61 | 14 | 63 | 55 | 41 | yes |
| total suspended solids | mg/L | every 6 days | 61 | 66 | 280 | 200 | 170 | yes |

| 90 percentile yearly summary | | | | | | | | |
|---------------------------------|-----------------|--|-------------------|----------------|----------------|---------------------|---------------------|---------------|
| EPA Point 8 Site code NH0008 | | Point description: In effluent channel downstream of the dropshaft | | | | | | |
| pollutant | unit of measure | sampling frequency | number of samples | minimum result | maximum result | 90 percentile limit | 90 percentile value | within limits |
| aluminium | ug/L | monthly | 12 | 337 | 772 | 1,700 | 691 | yes |
| chlorpyrifos | ug/L | monthly | 12 | <0.05 | <0.05 | 0.2 | <0.05 | yes |
| copper | ug/L | monthly | 12 | 32.3 | 136 | 300 | 127 | yes |
| hydrogen sulphide (unionised) | ug/L | monthly | 12 | <30 | 120 | 270 | 53 | yes |
| nonylphenol ethoxylate | ug/L | monthly | 12 | 15 | 147 | 253 | 133 | yes |
| oil and grease | mg/L | every 6 days | 61 | 14 | 63 | 70 | 54 | yes |
| total suspended solids | mg/L | every 6 days | 61 | 66 | 280 | 250 | 220 | yes |

North Head Wastewater Treatment Plant

2022-23 Pollution monitoring yearly limit summaries



EPL 378

Summary period: 01-07-2022 to 30-06-2023

Date published: 1-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

| 90 percentile yearly summary | | | | | | | | |
|---------------------------------|-----------------|--|-------------------|----------------|----------------|---------------------|---------------------|---------------|
| EPA Point 8 Site code NH0008 | | Point description: In effluent channel downstream of the dropshaft | | | | | | |
| pollutant | unit of measure | sampling frequency | number of samples | minimum result | maximum result | 90 percentile limit | 90 percentile value | within limits |
| sea urchin fertilisation (EC50) | % Effluent/Vol | monthly | 12 | 0.44 | 4.5 | 0.13 | 0.9 | yes |

| Average yearly summary | | | | | | | | |
|---------------------------------|-----------------|--|-------------------|----------------|----------------|---------------|---------------|---------------|
| EPA Point 8 Site code NH0008 | | Point description: In effluent channel downstream of the dropshaft | | | | | | |
| pollutant | unit of measure | sampling frequency | number of samples | minimum result | maximum result | Average Limit | Average value | within limits |
| aluminium | ug/L | monthly | 12 | 337 | 772 | 890 | 559 | yes |
| chlorpyrifos | ug/L | monthly | 12 | <0.05 | <0.05 | 0.09 | <0.05 | yes |
| copper | ug/L | monthly | 12 | 32.3 | 136 | 160 | 95 | yes |
| hydrogen sulphide (unionised) | ug/L | monthly | 12 | <30 | 120 | 143 | <30 | yes |
| nonylphenol ethoxylate | ug/L | monthly | 12 | 15 | 147 | 178 | 77 | yes |
| sea urchin fertilisation (EC50) | % Effluent/Vol | monthly | 12 | 0.44 | 4.5 | 0.24 | 2.3 | yes |