

# Warriewood Wastewater Treatment Plant

## 2021-22 Pollution monitoring yearly limit summaries



### EPL 1784

Summary period: 01-07-2021 to 30-06-2022

Date published: 19-08-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	380,000	200	8	yes
total suspended solids	mg/L	every 6 days	61	<2	37	30	4	yes

80 percentile yearly summary								
EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
total suspended solids	mg/L	every 6 days	61	<2	37	40	8	yes

90 percentile yearly summary								
EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	5	157	150	30	yes
copper	ug/L	monthly	12	2.1	17.4	30	8.3	yes
cyanide	ug/L	monthly	12	<5	17	30	17	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	<5	22	<5	yes

# Warriewood Wastewater Treatment Plant

## 2021-22 Pollution monitoring yearly limit summaries



### EPL 1784

Summary period: 01-07-2021 to 30-06-2022

Date published: 17-08-2022

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	8.1	41.1	4	21.4	yes

Average yearly summary								
EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	5	157	80	26	yes
copper	ug/L	monthly	12	2.1	17.4	15	6	yes
cyanide	ug/L	monthly	12	<5	17	17	10	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	<5	11	<5	yes
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	8.1	41.1	6.7	27.6	yes

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).