

Requirements for publishing monitoring data

What are licence limits?

Licence limits are the minimum or maximum values permitted for pollutants discharged under an environmental protection licence.

Why does Sydney Water have them?

Limits define the levels of pollutants permitted in discharges from Sydney Water's treatment plants.

Can a sample exceed its licence limit value without breaching the licence?

Within a licence for each pollutant listed by the EPA, it will have a limit value. This value may be a 100 percentile limit where samples must meet the limit value 100% of the time. Or for other pollutants lower percentile limits may be assigned. Where there are limit values lower than a 100% limit, a sample or samples test results can exceed the limit value. For example, if a 90 percentile limit is assigned to a pollutant, this means 90% of collected samples should meet the limit value. If 10 samples are required in a year only one sample of the ten samples for the year is allowed to exceed the 90 percentile limit value. If more than one sample exceeds this value this would be a non-compliance of the licence conditions.

What happens if we exceed licence limits?

If licence limits are exceeded more times than permitted under a licence, we report these non-compliances to the NSW EPA.

What has changed with this new reporting?

This new reporting requirement means that, for the first time, monthly summaries of pollution monitoring data under environmental pollution licences must be published on the internet within 14 days of the sample data being obtained.

Raw data collected under environmental protection licences must also be provided within 14 days of a request.

Why has it changed?

Changes in the Protection of Environment Operations Act (POEO Act), now require licensees with a public website to publish monthly summaries of pollution monitoring data within 14 days of the data being obtained.

When did it change?

The NSW EPA issued new requirements for publishing pollution monitoring data in March 2012.

Why are they different for each plant?

Sydney Water has a number of environmental protection licences and the limits and pollutants specified for each plant have been determined depending on a number of factors such as the technology used to treat discharges and the type of receiving environment.

Why aren't all the reports published at the same time?

The requirement is that data is published within 14 days of obtaining the data. Sydney Water samples its discharges at different times so therefore data is obtained on different days during the month and is published according to its availability to meet the 14-day timeframe.

What is Sydney Water doing to protect the environment?

Our treatment plants are run to minimise impacts on the environment, with ongoing benefit to our customers and the community. To find out more about recent initiatives and outcomes see our [Annual Report](#) at sydneywater.com.au/annualreport or visit the Water and the environment section of our website.

What if I want more information?

If you want more information, email us at epareports@sydneywater.com.au.