

# St Marys Wastewater Treatment Plant 2016-17 Pollution Monitoring Summary

## EPL 1729

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017



**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary								
EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	<2	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	>100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	60	0.01	1.5	1	0.02	yes
total suspended solids	mg/L	every 6 days	60	<2	4	10	<2	yes

# St Marys Wastewater Treatment Plant 2016-17 Pollution Monitoring Summary



## EPL 1729

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 2: 80 percentile yearly summary								
EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	84	200	2	yes

# St Marys Wastewater Treatment Plant

## 2016-17 Pollution Monitoring Summary

EPL 1729

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017



Licensee: Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 3: 90 percentile yearly summary**

EPA Point 5 Site code SM0005	Point description: At the outlet of the chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	40	158	1,100	108	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	<2	15	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.57	0.1	<0.04	yes
copper	ug/L	monthly	12	1.5	3.1	90	2.8	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	3.7	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	180	<30	yes
iron	ug/L	monthly	12	23	184	800	142	yes
nickel	ug/L	monthly	12	2.1	3.2	16.9	2.9	yes
nitrogen (ammonia)	mg/L	every 6 days	60	0.01	1.5	5	0.2	yes
total suspended solids	mg/L	every 6 days	60	<2	4	15	<2	yes
zinc	ug/L	monthly	12	11	52	100	42	yes

# St Marys Wastewater Treatment Plant 2016-17 Pollution Monitoring Summary

EPL 1729

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017



**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 4: 100 percentile yearly summary**

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
nitrogen (total)	mg/L	every 6 days	60	2.5	5.71	45	5.71	yes
phosphorus	mg/L	every 6 days	60	0.01	0.09	5	0.09	yes

# St Marys Wastewater Treatment Plant 2016-17 Pollution Monitoring Summary

EPL 1729

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017



**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 5: Average yearly summary**

EPA Point 5 Site code SM0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	40	158	120	76	yes
copper	ug/L	monthly	12	1.5	3.1	17.6	2.3	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.6	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	66	<30	yes
iron	ug/L	monthly	12	23	184	430	63	yes
nickel	ug/L	monthly	12	2.1	3.2	12.3	3	yes
zinc	ug/L	monthly	12	11	52	40	23	yes