





DETAIL
SCALE 1:5



DETAIL
SCALE 1:5




DETAIL
SCALE 1:5


THIS DRAWING MAY ONLY BE USED IN THE COURSE OF AND FOR THE PURPOSE OF CREATING SYDNEY WATER ASSETS. USE THIS DRAWING WITH CARE. THE USER IS RESPONSIBLE FOR THE CORRECT APPLICATION OF THIS DRAWING. THE USE OF DTC DRAWINGS IS SUBJECT TO TERMS AND CONDITIONS AS PUBLISHED BY SYDNEY WATER.

NOTES:

1. ALL BRACKETS LOCATED IN WET WELL TO BE GRADE 316 STAINLESS STEEL.
2. FIX BRACKET 300 CLEAR OF ANY SHAFT RING JOINTS AND 100 CLEAR OF BLOCKOUT OR CORED PENETRATIONS.
3. CONDUIT SUPPORT ONLY REQUIRED WHERE CONDUITS PENETRATE WALL BY MORE THAN 400mm.



DETAIL
SCALE 1:5



DETAIL
SCALE 1:5

Sydney
WATER

© COPYRIGHT
STATE OF NEW SOUTH WALES THROUGH SYDNEY
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED

NORBERT SCHAEFER
MANAGER - ENGINEERING

ENGINEERING & TECHNICAL SUPPORT

DEEMED TO COMPLY DRAWINGS

SEWAGE PUMPING STATION
PIPEWORK BRACKET
DETAILS

DTC

6039

ISSUE DATE
A 25/06/21

A ORIGINAL ISSUE (PREVIOUSLY DRAWING DTC/6021) NS 25/06/21
LETTER DETAILS OF ISSUE / AMENDMENT APP'D DATE