





## NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
2. PIPELINE DESIGN BASED ON MAXIMUM DESIGN PRESSURE OF 120m AND TEST PRESSURE OF 150m OF WATER.
3. DESIGN IS NOT SUITABLE FOR APPLICATION IN AGGRESSIVE OR CONTAMINATED SOIL CONDITIONS.
4. ALL FLANGES SHALL BE TO DTC/1145. ALL FASTENERS SHALL BE GRADE 316 STAINLESS STEEL.
5. ALL DI FITTINGS SHALL BE COATED TO AS/NZS 4158.
6. WHERE PROPRIETARY PRODUCTS ARE SPECIFIED, THE PRODUCTS SHALL BE INSTALLED STRICTLY IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.
7. THIS DRAWING SHALL BE READ IN IN CONJUNCTION WITH THE FOLLOWING DEEMED TO COMPLY DRAWINGS.  
A) DTC/1145 - PN16 FLANGE CONNECTION DETAILS  
A) DTC/1212 - AIR VALVE AND HYDRANT INSTALLATIONS - DETAILS



NOTE: SHROUD DISC, COLLAR AND SUPPORT BASE BY PENTAIR OR APPROVED EQUIVALENT



**Sydney**  
**WATER**

APPROVED

PETER GILLMAN  
MANAGER - E & ES

DEEMED TO COMPLY DRAWINGS

**HYDRANT INSTALLATIONS**  
**OFFSET FIRE FIGHTING ACCESSIBLE**

**DI, PVC & GRP WATER MAINS DN375 - DN750**

**DTC**  
**1208**

ISSUE	DATE
<b>A</b>	01/03/13

© COPYRIGHT  
STATE OF NEW SOUTH WALES THROUGH SYDNEY  
WATER CORPORATION. ALL RIGHTS RESERVED

ENGINEERING &amp; ENVIRONMENTAL SERVICES

A  
LETTER

ORIGINAL ISSUE

DETAILS OF ISSUE / AMENDMENT

PJG 01/03/13

APP'D DATE