

Bondi Wastewater Treatment Plant 2021-22 Air quality pollution monitoring summary



EPL 1688

Summary period: 01-07-2021 to 30-06-2022
Date published : 19-08-2022

Licensee: Sydney Water
PO Box 399
PARRAMATTA NSW 2124

Table 1: Routine monitoring data

EPA Point 11	Point description: Air sampling outlet of cogeneration facility					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	431	440	447

Yearly measurement was taken on 23-02-2022.