

Liverpool Wastewater Treatment Plant

2022-2023 Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile yearly summary

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
biochemical oxygen demand	mg/L	on bypass	71	8	63	300	100	300	no ¹
total suspended solids	mg/L	on bypass	71	12	44	200	100	200	no ¹

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather. ¹Details of any within limit exceptions were provided in monthly reports

Table 2: Average yearly summary

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	71	8	63	300
faecal coliforms	CFU/100mL	on bypass	71	600	2017586	7,000,000
total suspended solids	mg/L	on bypass	71	12	44	200

Liverpool Wastewater Treatment Plant

2022-2023 Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile yearly summary

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
biochemical oxygen demand	mg/L	monthly	12	<2	<2	<2	100	<2	yes
total suspended solids	mg/L	monthly	12	5	7	11	100	11	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Average yearly summary

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	monthly	12	<2	<2	<2
total suspended solids	mg/L	monthly	12	5	7	11

Liverpool Wastewater Treatment Plant

2022-2023 Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2022 to 30-06-2023

Date published: 01-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile yearly summary

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
biochemical oxygen demand	mg/L	on bypass	9	6	30	87	100	87	yes
total suspended solids	mg/L	on bypass	9	18	41	71	100	71	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Average yearly summary

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	9	6	30	87
faecal coliforms	CFU/100mL	on bypass	9	5	118034	460,000
total suspended solids	mg/L	on bypass	9	18	41	71