

# Quakers Hill Wastewater Treatment Plant 2021-22 Pollution Monitoring Summary



## EPL 1724

Summary period: 01-07-2021 to 30-06-2022

Date published: 30-08-2022

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 50 percentile yearly summary								
EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	<2	10	<2	yes
biochemical oxygen demand	mg/L	every 6 days	60	<2	8	10	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	60	0.01	4.23	0.9	0.13	yes
total suspended solids	mg/L	every 6 days	60	<2	5	0.5	<2	yes

Table 1: 50 percentile yearly summary								
EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes

# Quakers Hill Wastewater Treatment Plant

## 2021-22 Pollution Monitoring Summary



### EPL 1724

Summary period: 01-07-2021 to 30-06-2022

Date published: 30-08-2022

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 2: 80 percentile yearly summary**

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	250	200	17	yes

# Quakers Hill Wastewater Treatment Plant 2021-22 Pollution Monitoring Summary

EPL 1724

Summary period: 01-07-2021 to 30-06-2022

Date published: 30-08-2022



Licensee: Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 3: 90 percentile yearly summary**

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
aluminium	ug/L	monthly	12	58	360	190	161	yes
cadmium	ug/L	monthly	12	<0.1	<0.1	0.3	<0.1	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	60	<2	<2	15	<2	yes
biochemical oxygen demand	mg/L	every 6 days	60	<2	8	15	<2	yes
chromium	ug/L	monthly	12	<0.2	1.5	4	1.2	yes
cobalt	ug/L	bi-annually	2	0.3	0.5	-	0.5	n/a
copper	ug/L	monthly	12	1.4	8.2	6	4.1	yes
manganese	ug/L	bi-annually	12	2.8	105	-	38.1	n/a
molybdenum	ug/L	bi-annually	2	1.4	1.9	-	1.9	n/a
nickel	ug/L	bi-annually	2	1.8	2.4	-	2.4	n/a
nitrogen (ammonia)	mg/L	every 6 days	60	0.01	4.23	1.4	0.6	yes
total suspended solids	mg/L	every 6 days	60	<2	5	15	<2	yes
zinc	ug/L	monthly	12	10	25	41	22	yes

**Table 3: 90 percentile yearly summary**

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limit
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.04	0.1	<0.04	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	160	<30	yes

# Quakers Hill Wastewater Treatment Plant 2021-22 Pollution Monitoring Summary

EPL 1724

Summary period: 01-07-2021 to 30-06-2022

Date published: 30-08-2022



**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 4: 100 percentile yearly summary**

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	100 percentile limit	100 percentile value	within limits
nitrogen (total)	mg/L	every 6 days	60	2.42	8.32	45	8.32	yes
phosphorus	mg/L	every 6 days	60	0.03	0.31	5	0.31	yes

# Quakers Hill Wastewater Treatment Plant 2021-22 Pollution Monitoring Summary

EPL 1724

Summary period: 01-07-2021 to 30-06-2022

Date published: 30-08-2022



**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

**Table 5: Average yearly summary**

EPA Point 4 Site code QH0004		Point description: Downstream of the overflow weir in the clean water tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
aluminium	ug/L	monthly	12	58	360	120	117	yes
cadmium	ug/L	monthly	12	<0.1	<0.1	0.2	<0.1	yes
chromium	ug/L	monthly	12	<0.2	1.5	3	1	yes
cobalt	ug/L	bi-annually	2	0.3	0.5	-	0.4	n/a
copper	ug/L	monthly	12	1.4	8.2	5	3	yes
manganese	ug/L	bi-annually	2	<0.01	38.1	-	43	n/a
molybdenum	ug/L	bi-annually	2	1.4	1.9	-	2	n/a
nickel	ug/L	bi-annually	2	1.8	2.4	-	2	n/a
zinc	ug/L	monthly	12	10	25	34	16	yes

**Table 5: Average yearly summary**

EPA Point 5 Site code QH0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	30	<30	yes

Effluent quality monitoring results obtained from EPA Points 4 and 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).