


## NOTES:


1. REFER TO DRAWING DTC/6028 FOR FIXED COVER ARRANGEMENT.



FIXED COVER 6 - VALVE ACTUATOR SUPPORT



SCALE 1:10

STAINLESS STEEL TO BE GRADE 316L




FIXED COVER 6a - NO ACTUATOR

SCALE 1:10



FIXED COVER 7

SCALE 1:10



FIXED COVER 8

SCALE 1:10

Sydney  
**WATER**

© COPYRIGHT  
STATE OF NEW SOUTH WALES THROUGH SYDNEY  
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED

NORBERT SCHAEFER  
MANAGER - ENGINEERING

ENGINEERING & TECHNICAL SUPPORT

B  
A  
LETTER

GENERAL UPDATE (NEW DETAIL DRAWING)  
ORIGINAL ISSUE

DETAILS OF ISSUE / AMENDMENT

NS  
KW  
APP'D  
DATE

DEEMED TO COMPLY DRAWINGS

SEWAGE PUMPING STATION  
WET WELL DN3600, ACCESS HATCHES  
& SAFETY GRILLES - DETAILS

DTC

6032

ISSUE  
B

DATE  
25/06/21