


- NOTES
- 1. SITE STRUCTURES, PIPEWORK AND CONDUITS SHOWN INDICATIVE ONLY. LAYOUT IS TO BE DESIGNED FOR EACH SITE SPECIFIC APPLICATION AND DETAILED ON A SITE SPECIFIC PLAN.
 - 2. FOR FURTHER DETAILS OF PUMP STATION REFER DRAWING NO. DTC/6011 - DTC/6013.
 - 3. WATER TO DRAIN AWAY FROM STRUCTURES AND ELECTRICAL PITS.
 - 4. THE PROPERTY BOUNDARY SHALL ENCOMPASS ANY EARTHWORKS REQUIRED TO DELIVER THE PUMPING STATION. IN THE CASE OF A CUTTING, THE PROPERTY BOUNDARY SHALL BE LOCATED AT LEAST 1500mm BEYOND THE TOP OF THE CUT. IN THE CASE OF THE EMBANKMENT, THE BOUNDARY SHALL BE LOCATED 1500mm BEYOND THE TOE OF THE EMBANKMENT.
 - 5. THE SITE FENCE SHALL BE LOCATED AT THE PROPERTY BOUNDARY. WHERE THE NEIGHBOURING LAND USE IS OPEN SPACE / RECREATION, AND SUBJECT TO THE RELEVANT LOCAL GOVERNMENT AUTHORITY, THE FENCE MAY BE LOCATED AT THE TOP OF EMBANKMENTS ENHANCING THE AESTHETIC VALUE OF THE OPEN SPACE. OWNERSHIP AND EASEMENT CONDITIONS OF BATTER SLOPES BEYOND THE FENCE LINE MUST BE CONFIRMED WITH SYDNEY WATER & SHALL BE BASED ON PROJECT SPECIFIC REQUIREMENTS.
 - 6. SITE STORMWATER OUTLET TO EITHER PUBLIC STORMWATER DRAINAGE SYSTEM OR PIPED TO WATERWAY/CREEK.
 - 7. SITE SPECIFIC DESIGN TO NOMINATE CONSTRUCTION JOIN, SAW CUT, TOOLED AND ISOLATION JOINT LOCATIONS.

- LEGEND:
- 40mm SINGLE SIZE GRAVEL
150 DEEP WITH WEED MAT UNDER
 - HARDSTAND AREA
 - LANDSCAPE TREES/SHRUBS
 - TRUCK FORWARD TURNING PATH

THIS DRAWING IS NOT FOR CONSTRUCTION.
THE USER SHALL PREPARE A SITE SPECIFIC SITE PLAN

EXAMPLE SITE LAYOUT 3 - SITE PLAN
SCALE 1:200



<div>Sydney</div> <div>WATER</div> <div>©COPYRIGHT</div> <div>STATE OF NEW SOUTH WALES THROUGH SYDNEY WATER CORPORATION. ALL RIGHTS RESERVED</div>	APPROVED	<div>NORBERT SCHAEPER</div> <div>MANAGER – ENGINEERING</div>					DEEMED TO COMPLY DRAWINGS		<div>DTC</div> <div>6007</div>	
			SEWAGE PUMPING STATION EXAMPLE SITE LAYOUT 3 SITE PLAN						ISSUE	DATE
	ENGINEERING & TECHNICAL SUPPORT	B	GENERAL UPDATE (PREVIOUSLY DRAWING DTC/6003)			NS	25/06/21	B	25/06/21	
		A	ORIGINAL ISSUE			KW	22/06/15			
	LETTER	DETAILS OF ISSUE / AMENDMENT			APP'D	DATE				