



## NOTES

- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE DEEMED TO COMPLY DRAWINGS ON DTC/6301.
- FOR ASSEMBLY AND GENERAL NOTES REFER TO DTC/6304 & DTC/6301.
- PRECAST ROOF SLABS HAVE NOT BEEN DESIGNED FOR VEHICULAR LOADING.
- PROVIDE COG ON BOTH ENDS TO LAP TOP AND BOTTOM REINFORCEMENT BARS AS SHOWN.
- CLEAR COVER TO ALL REINFORCEMENT TO BE 55mm U.N.O.

**Sydney  
WATER**© COPYRIGHT  
STATE OF NEW SOUTH WALES THROUGH SYDNEY  
WATER CORPORATION. ALL RIGHTS RESERVED

APPROVED

NORBERT SCHAEFER  
ENGINEERING MODERNISATION MANAGER

ENGINEERING &amp; TECHNICAL SERVICES

B  
A  
LETTERGENERAL UPDATE  
ORIGINAL ISSUE

DETAILS OF ISSUE / AMENDMENT

NS  
KW  
APP'D  
31/07/24  
22/06/15  
DATEDEEMED TO COMPLY DRAWINGS  
TEMPORARY SEWAGE PUMP-OUT INSTALLATIONS  
STORAGE TANKS - STRUCTURAL  
PRECAST ROOF TYPE A - SHAFT RING**DTC  
6307**ISSUE  
B  
DATE  
31/07/24