

Concentration Limit Table

St Marys Water Resource Recovery Facility

Air Quality

EPL 1729

Sydney Water's Water Resource Recovery Facilities operate under environmental protection licences issued by the NSW Environment Protection Authority (EPA). For each monitoring/discharge point the concentration of a pollutant must not exceed the concentration limits specified for that pollutant in the table.

pollutant	unit of measure	maximum limit
nitrogen oxides	mg/m ³	450

Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2022 - Schedule 2 - Part 2 Scheduled premises - Division 3 General activities and plant - General standards of concentration