

## Concentration Limit Table

### Warriewood Wastewater Treatment Plant

### Air Quality

**EPL 1784**

Sydney Water's treatment plants operate under environmental protection licences issued by the NSW Environmental Protection Authority (EPA). For each monitoring/discharge point the concentration of a pollutant must not exceed the concentration limits specified for that pollutant in the table.

pollutant	unit of measure	maximum limit
nitrogen oxides	mg/m <sup>3</sup>	450

Maximum limits for air quality are based on the *Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.*