

EPL 372



Date published: 03-09-2026

PARRAMATTA NSW 2124

Table 1: Routine monitoring data

EPA Point 1		Point description: Air sampling outlet of the foul air scrubbers					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*
chlorine gas	mg/m ³	30 minutes	1488	<0.30	0.62	200	yes
hydrogen sulphide gas	mg/m ³	30 minutes	1488	<0.07	0.40	5	yes

**Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2022 - Schedule 2 - Part 2 Scheduled premises - Division 3 General activities and plant - General standards of concentration*