

Bondi Wastewater Treatment Plant

2022-23 Air quality pollution monitoring summaries

EPL 1688

Summary period: 1-07-2022 to 30-06-2023

Date published: 01-09-2023

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 11	Point description: Air sampling outlet of cogeneration facility					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	4	438	445	450

Yearly measurement was taken on 29-11-2022.