

Bondi Water Resource Recovery Facility

2025-26 Air Quality Pollution Monitoring Summary

EPL 1688

Summary period: 1-07-2025 to 30-06-2026

Date published: 07-05-2026

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 12	Point description: Air sampling outlet of cogeneration facility					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	304	311	316

Measurements were taken on 28-11-2025.