

Malabar Wastewater Treatment System

2025-26 Air Quality Pollution Monitoring Summary



EPL 372

Summary period: 1-07-2025 to 30-06-2026

Date published: 07-05-2026

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 84		Point description: Air sampling outlet of cogeneration facility at Malabar WRRF				
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
nitrogen oxides	mg/m ³	yearly	6	321	338	353

Measurements were taken on 04-12-2025.

EPA Point 85		Point description: Air sampling outlet of cogeneration facility at Glenfield WRRF				
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
nitrogen oxides	mg/m ³	yearly	3	342	345	347

Measurements were taken on 08-12-2025.

EPA Point 86		Point description: Air sampling outlet of cogeneration facility at Liverpool WRRF				
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
nitrogen oxides	mg/m ³	yearly	3	334	341	348
oxygen (O ₂)	percent	yearly	3	8.01	8.05	8.09

Measurements were taken on 08-12-2025.