North Head Wastewater Treatment Plant 2022-23 Air quality pollution monitoring summaries



EPL 378 Licensee: Sydney Water

Summary period: 1-07-2022 to 30-06-2023 PO Box 399

Date published: 01-09-2023 PARRAMATTA NSW 2124

EPA Point 33	Point descr	Point description: Ventilation outlet at Scotts Creek									
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*			
hydrogen sulphide gas	mg/m ³	30 minutes	17517 ¹	<0.004	<0.004	0.005	5	100%			

EPA Point 34	Point descr	Point description: Ventilation outlet at Lane Cove River West									
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*			
hydrogen sulphide gas	mg/m ³	30 minutes	16389 ¹	<0.004	<0.004	0.113	5	100%			

EPA Point 35	Point descr	oint description: Ventilation outlet at North Head STP for Northside Storage Tunnel								
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*		
hydrogen sulphide gas	mg/m ³	30 minutes	17518 ¹	<0.01	0.01	7.10	5	>99.9% ²		

Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.

¹ Commentary for data loss are included in 2022-23 monthly summary reports

² Commentary for exceedances are included in 2022-23 monthly summary reports.

North Head Wastewater Treatment Plant 2022-23 Air quality pollution monitoring summaries



EPL 378 Licensee: Sydney Water

Summary period: 1-07-2022 to 30-06-2023 PO Box 399

Date published: 01-09-2023 PARRAMATTA NSW 2124

EPA Point 63	Point description: Central scrubber outlet at North Head STP									
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*		
chlorine gas	mg/m ³	30 minutes	17518 ¹	<0.15	0.15	5.97	200	100%		
hydrogen sulphide gas	mg/m ³	30 minutes	17518 ¹	<0.075	0.082	2.13	5	100%		

EPA Point 66	Point description: Bio Trickling Filter / Standby Scrubber at North Head STP									
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*		
chlorine gas	mg/m ³	30 minutes	17518 ¹	<0.59	<0.59	1.91	200	100%		
hydrogen sulphide gas	mg/m ³	30 minutes	17518 ¹	<0.071	0.152	19.5	5	>99.9%2		

Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.

¹ Commentary for data loss are included in 2022-23 monthly summary reports

² Commentary for exceedances are included in 2022-23 monthly summary reports.



North Head Wastewater Treatment Plant 2022-23 Air quality pollution monitoring summaries

Summary period: 1-07-2022 to 30-06-2023 Licensee: Sydney Water

Date published: 01-09-2023

PARRAMATTA NSW 2124

PO Box 399

EPA Point 64	Point description: Air sampling outlet of cogeneration facility unit 1 at North Head STP								
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result			
nitrogen oxides	mg/m ³	yearly	3	318	335	359			

Yearly measurement was taken on 09-12-2022.

EPA Point 65	Point description: Air sampling outlet of cogeneration facility unit 2 at North Head STP								
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result			
nitrogen oxides	mg/m ³	yearly	3	362	431	462			

Yearly measurement was taken on 09-12-2022.