

North Head Wastewater Treatment Plant

2024-25 Air quality pollution monitoring summaries



EPL 378

Summary period: 1-07-2024 to 30-06-2025

Date published: 01-09-2025

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 33		Point description: Ventilation outlet at Scotts Creek						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
hydrogen sulphide gas	mg/m ³	30 minutes	17,518 ¹	<0.004	<0.004	0.028	5	100

EPA Point 34		Point description: Ventilation outlet at Lane Cove River West						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
hydrogen sulphide gas	mg/m ³	30 minutes	17,518 ¹	<0.004	<0.004	0.128	5	100

EPA Point 35		Point description: Ventilation outlet at North Head STP for Northside Storage Tunnel						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
hydrogen sulphide gas	mg/m ³	30 minutes	17,518 ¹	<0.01	<0.01	2.94	5	100

*Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.

¹ Commentary for data loss are included in 2024-25 monthly summary reports.

North Head Wastewater Treatment Plant

2024-25 Air quality pollution monitoring summaries



EPL 378

Summary period: 1-07-2024 to 30-06-2025

Date published: 01-09-2025

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 63		Point description: Central scrubber outlet at North Head STP						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
chlorine gas	mg/m ³	30 minutes	17,518	<0.15	0.29	29.50	200	100
hydrogen sulphide gas	mg/m ³	30 minutes	17,518	<0.075	0.103	2.130	5	100

EPA Point 66		Point description: Bio Trickling Filter / Standby Scrubber at North Head STP						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
chlorine gas	mg/m ³	30 minutes	17,518	<0.59	<0.59	1.19	200	100
hydrogen sulphide gas	mg/m ³	30 minutes	17,518	0.098	0.139	2.328	5	100

*Maximum limits for air quality are based on the Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.

North Head Wastewater Treatment Plant

2024-25 Air quality pollution monitoring summaries

Summary period: 1-07-2024 to 30-06-2025

Date published: 01-09-2025

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 64		Point description: Air sampling outlet of cogeneration facility unit 1 at North Head STP				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	337	362	383

Yearly measurement was taken on 22-11-2024.

EPA Point 65		Point description: Air sampling outlet of cogeneration facility unit 2 at North Head STP				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	328	362	418

Yearly measurement was taken on 22-11-2024.