

North Head Water Resource Recovery Facility

2025-26 Air Quality Pollution Monitoring Summary

EPL 378

Summary period: 1-07-2025 to 30-06-2026

Date published: 07-05-2026

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 64		Point description: Air sampling outlet of cogeneration facility unit 1 at North Head WRRF				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	0*	NA	NA	NA

*No measurements taken due to asset being damaged beyond repair. A replacement project is underway, and target commissioning of the new asset will be in Quarter 3 or 4 of the 2026-27 financial year. A report will be compiled during the commissioning phase.

EPA Point 65		Point description: Air sampling outlet of cogeneration facility unit 2 at North Head WRRF				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	376	378	380

Measurements were taken on 25-11-2025.