Wollongong Wastewater Treatment Plant 2019-20 Air quality pollution monitoring summary



EPL 218

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water PO Box 399

PARRAMATTA NSW 2124

Table 1: Routine monitoring data

EPA Point 29	Point description: Air sampling outlet of cogeneration facility					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	429	436	446

Yearly measurement taken on 24-04-2020.