

# Bombo Water Resource Recovery Facility

## March Pollution Monitoring Summary



### EPL 2269

Summary period: 01-03-2024 to 31-03-2024

Date obtained: 08-04-2024

Date published: 18-04-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	<2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	21
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	3	9

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	364	1,600
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## February Pollution Monitoring Summary



### EPL 2269

Summary period: 01-02-2024 to 29-02-2024

Date obtained: 11-03-2024

Date published: 22-03-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	6	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	37
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	5
copper	ug/L	monthly	1	-	-	3.8
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.9
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	8	29

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	3	165	800
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## January Pollution Monitoring Summary



### EPL 2269

Summary period: 01-01-2024 to 31-01-2024

Date obtained: 05-02-2024

Date published: 19-02-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	27
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.5
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	6.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	12
total suspended solids	mg/L	every 6 days	5	<2	3	4

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	70	340
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## December Pollution Monitoring Summary



### EPL 2269

Summary period: 01-12-2023 to 31-12-2023

Date obtained: 10-01-2024

Date published: 22-01-2024

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	9	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	45
biochemical oxygen demand	mg/L	every 6 days	5	<2	2	8
copper	ug/L	monthly	1	-	-	4.9
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	11
total suspended solids	mg/L	every 6 days	5	3	8	14

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	6	5	968	2,600
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## November Pollution Monitoring Summary



### EPL 2269

Summary period: 01-11-2023 to 30-11-2023

Date obtained: 13-12-2023

Date published: 19-12-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	29
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	6
copper	ug/L	monthly	1	-	-	4.3
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	1.3
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	3	6

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	10	36
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## October Pollution Monitoring Summary



### EPL 2269

Summary period: 01-10-2023 to 31-10-2023

Date obtained: 07-11-2023

Date published: 17-11-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	<2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	23
biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.7
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	1.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	6	<2	<2	3

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## September Pollution Monitoring Summary



### EPL 2269

Summary period: 01-09-2023 to 30-09-2023

Date obtained: 02-10-2023

Date published: 13-10-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	3	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	19
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	1.9
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	4

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	14	66
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Bombo Water Resource Recovery Facility

## August Pollution Monitoring Summary



### EPL 2269

Summary period: 01-08-2023 to 31-08-2023

Date obtained: 04-09-2023

Date published: 14-09-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	6	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	21
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	1.6
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	11.1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	5

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	4
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).



# Bombo Water Resource Recovery Facility

## July Pollution Monitoring Summary



### EPL 2269

Summary period: 01-07-2023 to 31-07-2023

Date obtained: 05-08-2023

Date published: 15-08-2023

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	50	<2	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	24
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.2
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.9
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2

  

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	3
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 4 and 13 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).