

Bondi Water Resource Recovery Facility

March Pollution Monitoring Summary



EPL 1688

Summary period: 01-03-2025 to 31-03-2025
Date obtained: 07-04-2025
Date published: 15-04-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	43	yes
total suspended solids	mg/L	monthly	290	104	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	124
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	75
nonylphenol ethoxylate	ug/L	monthly	1	-	-	160
oil and grease	mg/L	every 6 days	5	23	35	44
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	3.4
total suspended solids	mg/L	every 6 days	5	78	90	96

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the March monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

February Pollution Monitoring Summary



EPL 1688

Summary period: 01-02-2025 to 28-02-2025
Date obtained: 07-03-2025
Date published: 19-03-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	34	yes
total suspended solids	mg/L	monthly	290	91	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	174
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	51
nonylphenol ethoxylate	ug/L	monthly	1	-	-	145
oil and grease	mg/L	every 6 days	5	32	38	46
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.1
total suspended solids	mg/L	every 6 days	5	100	104	110

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the February monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

January Pollution Monitoring Summary



EPL 1688

Summary period: 01-01-2025 to 31-01-2025
Date obtained: 06-02-2025
Date published: 14-02-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	39	yes
total suspended solids	mg/L	monthly	290	116	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	205
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	147
nonylphenol ethoxylate	ug/L	monthly	1	-	-	143
oil and grease	mg/L	every 6 days	5	19	32	39
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	0.6
total suspended solids	mg/L	every 6 days	5	82	95	120

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the January monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

December Pollution Monitoring Summary



EPL 1688

Summary period: 01-12-2024 to 31-12-2024
Date obtained: 06-01-2025
Date published: 15-01-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	28	yes
total suspended solids	mg/L	monthly	290	108	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	215
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	132
oil and grease	mg/L	every 6 days	5	35	39	46
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	1.7
total suspended solids	mg/L	every 6 days	5	100	108	120

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the December monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

November Pollution Monitoring Summary



EPL 1688

Summary period: 01-11-2024 to 30-11-2024
Date obtained: 09-12-2024
Date published: 13-12-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	48	yes
total suspended solids	mg/L	monthly	290	142	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	269
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	158
oil and grease	mg/L	every 6 days	5	31	39	46
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	0.9
total suspended solids	mg/L	every 6 days	5	88	116	170

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the November monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

October Pollution Monitoring Summary



EPL 1688

Summary period: 01-10-2024 to 31-10-2024
Date obtained: 07-11-2024
Date published: 15-11-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	43	yes
total suspended solids	mg/L	monthly	290	97	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	178
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	146
nonylphenol ethoxylate	ug/L	monthly	1	-	-	184
oil and grease	mg/L	every 6 days	5	42	46	49
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	3.8
total suspended solids	mg/L	every 6 days	5	90	104	120

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the October monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

September Pollution Monitoring Summary



EPL 1688

Summary period: 01-09-2024 to 30-09-2024
Date obtained: 09-10-2024
Date published: 23-10-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	39	yes
total suspended solids	mg/L	monthly	290	91	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	147
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	177
oil and grease	mg/L	every 6 days	5	31	39	43
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.5
total suspended solids	mg/L	every 6 days	5	76	95	110

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the September monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

August Pollution Monitoring Summary



EPL 1688

Summary period: 01-08-2024 to 31-08-2024
Date obtained: 11-09-2024
Date published: 13-09-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	39	yes
total suspended solids	mg/L	monthly	290	98	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	165
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	136
oil and grease	mg/L	every 6 days	6	28	38	42
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.5
total suspended solids	mg/L	every 6 days	6	72	87	120

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the August monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

July Pollution Monitoring Summary



EPL 1688

Summary period: 01-07-2024 to 31-07-2024
Date obtained: 08-08-2024
Date published: 16-08-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	31	yes
total suspended solids	mg/L	monthly	290	80	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	213
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	159
oil and grease	mg/L	every 6 days	5	31	35	40
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	5.2
total suspended solids	mg/L	every 6 days	5	78	92	110

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the July monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).