

Bondi Water Resource Recovery Facility

August Pollution Monitoring Summary



EPL 1688

Summary period: 01-08-2025 to 31-08-2025
Date obtained: 02-09-2025
Date published: 12-09-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	24	yes
total suspended solids	mg/L	monthly	290	71	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	116
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	179
oil and grease	mg/L	every 6 days	5	22	27	37
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	3
total suspended solids	mg/L	every 6 days	5	59	73	84

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the August monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).

Bondi Water Resource Recovery Facility

July Pollution Monitoring Summary



EPL 1688

Summary period: 01-07-2025 to 31-07-2025
Date obtained: 31-07-2025
Date published: 14-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	70	38	yes
total suspended solids	mg/L	monthly	290	101	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code BN0005		Point description: In the effluent channel downstream of the sedimentation tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	147
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	115
oil and grease	mg/L	every 6 days	5	28	38	44
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.9
total suspended solids	mg/L	every 6 days	5	89	100	120

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 1688, collection of samples from EPA Point 8 is required when sewage or effluent is discharged from EPA Point 2. There was no discharge from EPA Point 2 during the July monitoring period.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (deep water ocean outfall).