

# Castle Hill Water Resource Recovery Facility

## June Pollution Monitoring Summary



### EPL 1725

Summary period: 01-06-2024 to 30-06-2024  
Date obtained: 08-07-2024  
Date published: 22-07-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	119
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	4.4
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	37
nitrogen (ammonia)	mg/L	every 6 days	5	0.29	0.72	1.6
nitrogen (total)	mg/L	every 6 days	5	7.49	10.27	12.7
phosphorus (total)	mg/L	every 6 days	5	0.04	0.05	0.08
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	19

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	24	20121	100,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## May Pollution Monitoring Summary



### EPL 1725

Summary period: 01-05-2024 to 31-05-2024  
Date obtained: 11-06-2024  
Date published: 21-06-2024

Licensee: Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	104
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	5.2
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	49
nitrogen (ammonia)	mg/L	every 6 days	5	0.1	0.21	0.33
nitrogen (total)	mg/L	every 6 days	5	10.9	15.04	18.2
phosphorus (total)	mg/L	every 6 days	5	0.03	0.04	0.04
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	<1	22	46
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## April Pollution Monitoring Summary



### EPL 1725

Summary period: 01-04-2024 to 30-04-2024  
 Date obtained: 06-05-2024  
 Date published: 20-05-2024

**Licensee:** Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	113
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	7.4
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	43
nitrogen (ammonia)	mg/L	every 6 days	5	0.07	0.29	0.74
nitrogen (total)	mg/L	every 6 days	5	11.7	16.26	20.7
phosphorus (total)	mg/L	every 6 days	5	0.03	0.04	0.06
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	16

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	12	10055	50,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## March Pollution Monitoring Summary



### EPL 1725

Summary period: 01-03-2024 to 31-03-2024  
Date obtained: 08-04-2024  
Date published: 18-04-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	166
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	9.9
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	54
nitrogen (ammonia)	mg/L	every 6 days	5	0.04	0.15	0.27
nitrogen (total)	mg/L	every 6 days	5	14.3	18.96	21.9
phosphorus (total)	mg/L	every 6 days	5	0.05	0.06	0.07
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	16

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	2	7	9
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## February Pollution Monitoring Summary



### EPL 1725

Summary period: 01-02-2024 to 29-02-2024  
Date obtained: 12-03-2024  
Date published: 25-03-2024

Licensee: Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	239
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
cobalt	ug/L	bi-annually	1	-	-	0.6
copper	ug/L	monthly	1	-	-	8
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	66
nitrogen (ammonia)	mg/L	every 6 days	5	0.13	0.68	1.29
nitrogen (total)	mg/L	every 6 days	5	14.5	17.3	19.5
phosphorus (total)	mg/L	every 6 days	5	0.05	0.07	0.09
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	15

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	15	99	330
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## January Pollution Monitoring Summary



EPL 1725

Summary period: 01-01-2024 to 31-01-2024  
 Date obtained: 05-02-2024  
 Date published: 19-02-2024

Licensee: Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	307
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	4
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	7.4
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	116
nitrogen (ammonia)	mg/L	every 6 days	5	0.08	0.23	0.43
nitrogen (total)	mg/L	every 6 days	5	9.1	15.88	18.5
phosphorus (total)	mg/L	every 6 days	5	0.03	0.03	0.04
total suspended solids	mg/L	every 6 days	5	<2	<2	2
zinc	ug/L	monthly	1	-	-	20

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	14	20040	100,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## December Pollution Monitoring Summary



### EPL 1725

Summary period: 01-12-2023 to 31-12-2023  
 Date obtained: 10-01-2024  
 Date published: 22-01-2024

**Licensee:** Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	183
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	7.2
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	80
nitrogen (ammonia)	mg/L	every 6 days	5	0.06	0.36	1.23
nitrogen (total)	mg/L	every 6 days	5	15.8	17.16	18.3
phosphorus (total)	mg/L	every 6 days	5	0.03	0.04	0.09
total suspended solids	mg/L	every 6 days	5	<2	<2	4
zinc	ug/L	monthly	1	-	-	19

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	6	<1	31	60
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).



# Castle Hill Water Resource Recovery Facility

## November Pollution Monitoring Summary



### EPL 1725

Summary period: 01-11-2023 to 30-11-2023

Date obtained: 13-12-2023

Date published: 19-12-2023

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	295
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	7.8
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	61
nitrogen (ammonia)	mg/L	every 6 days	5	0.03	0.46	0.75
nitrogen (total)	mg/L	every 6 days	5	12.4	15.7	18.8
phosphorus (total)	mg/L	every 6 days	5	0.04	0.06	0.07
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	2	67	270
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).



# Castle Hill Water Resource Recovery Facility

## October Pollution Monitoring Summary



### EPL 1725

Summary period: 01-10-2023 to 31-10-2023

Date obtained: 07-11-2023

Date published: 17-11-2023

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	174
biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	9.3
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	38
nitrogen (ammonia)	mg/L	every 6 days	6	0.06	0.2	0.63
nitrogen (total)	mg/L	every 6 days	6	16.1	19.1	20.4
phosphorus (total)	mg/L	every 6 days	6	0.04	0.07	0.12
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	19

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	1	13	36
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## September Pollution Monitoring Summary



### EPL 1725

Summary period: 01-09-2023 to 30-09-2023

Date obtained: 09-10-2023

Date published: 13-10-2023

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	140
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	7.1
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	37
nitrogen (ammonia)	mg/L	every 6 days	5	0.11	0.18	0.26
nitrogen (total)	mg/L	every 6 days	5	16.8	19.02	21.5
phosphorus (total)	mg/L	every 6 days	5	0.07	0.09	0.13
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	6	23	45
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## August Pollution Monitoring Summary



### EPL 1725

Summary period: 01-08-2023 to 31-08-2023

Date obtained: 05-09-2023

Date published: 14-09-2023

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	236
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
cobalt	ug/L	bi-annually	1	-	-	0.6
copper	ug/L	monthly	1	-	-	7.6
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	47
nitrogen (ammonia)	mg/L	every 6 days	5	0.06	0.59	1.09
nitrogen (total)	mg/L	every 6 days	5	16.2	19.2	21.4
phosphorus (total)	mg/L	every 6 days	5	0.11	0.12	0.14
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	18

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	<1	26	68
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

# Castle Hill Water Resource Recovery Facility

## July Pollution Monitoring Summary



### EPL 1725

Summary period: 01-07-2023 to 31-07-2023

Date obtained: 05-08-2023

Date published: 15-08-2023

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	10	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	199
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
copper	ug/L	monthly	1	-	-	7.2
diazinon	ug/L	monthly	1	-	-	<0.1
iron	ug/L	monthly	1	-	-	48
nitrogen (ammonia)	mg/L	every 6 days	5	0.18	0.4	0.56
nitrogen (total)	mg/L	every 6 days	5	17.3	19.16	21.2
phosphorus (total)	mg/L	every 6 days	5	0.1	0.12	0.13
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	23

EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
faecal coliforms	CFU/100mL	every 6 days	5	<1	6	13
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 5 and 6 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).