

# Glenfield Wastewater Treatment Plant

## May Pollution Monitoring Summary

### EPL 372



Summary period: 01-05-2020 to 31-05-2020

Date obtained: 28-05-2020

Date published: 11-06-2020

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	22	yes
total suspended solids	mg/L	on bypass	100	34	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	2	12	17	22
faecal coliforms	CFU/100mL	on bypass	2	110,000	130000	150,000
total suspended solids	mg/L	on bypass	2	21	28	34

# Glenfield Wastewater Treatment Plant

## February Pollution Monitoring Summary

### EPL 372



Summary period: 01-02-2020 to 29-02-2020

Date obtained: 18-02-2020

Date published: 03-03-2020

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	24	yes
total suspended solids	mg/L	on bypass	100	69	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	5	15	20	24
faecal coliforms	CFU/100mL	on bypass	5	1,900	1830380	6,300,000
total suspended solids	mg/L	on bypass	5	23	45	69

# Glenfield Wastewater Treatment Plant

## September Pollution Monitoring Summary

### EPL 372



Summary period: 01-09-2019 to 30-09-2019

Date obtained: 25-09-2019

Date published: 08-10-2019

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

**Table 1: 100 percentile data**

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	49	yes
total suspended solids	mg/L	on bypass	100	19	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

**Table 2: Routine monitoring data**

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	1	-	-	49
faecal coliforms	CFU/100mL	on bypass	1	-	-	<1
total suspended solids	mg/L	on bypass	1	-	-	19