

Glenfield Water Resource Recovery Facility

July Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2026 to 31-07-2026
Date obtained: 01-08-2026
Date published: 15-08-2026

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	on bypass	100	-	-
total suspended solids	mg/L	on bypass	100	-	-

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
biochemical oxygen demand	mg/L	on bypass	0	-	-	-
faecal coliforms	CFU/100mL	on bypass	0	-	-	-
total suspended solids	mg/L	on bypass	0	-	-	-

As per clause M2.4 under EPL 372, collection of samples is required from GF0020 after 3 hours of continuous discharge from EPA Point 20. There was no discharge from EPA ID 20 during the July monitoring period.