

# North Head Water Resource Recovery Facility

## June Pollution Monitoring Summary



### EPL 378

Summary period: 01-06-2025 to 30-06-2025  
Date obtained: 08-07-2025  
Date published: 22-07-2025

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	35	yes
total suspended solids	mg/L	monthly	290	149	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	389
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	81.5
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	62
oil and grease	mg/L	every 6 days	5	34	42	48
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	0.5
total suspended solids	mg/L	every 6 days	5	140	190	230

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the June monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## May Pollution Monitoring Summary



### EPL 378

Summary period: 01-05-2025 to 31-05-2025  
 Date obtained: 10-06-2025  
 Date published: 23-06-2025

**Licensee:** Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	31	yes
total suspended solids	mg/L	monthly	290	169	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	353
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	82.1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	157
nonylphenol ethoxylate	ug/L	monthly	1	-	-	27
oil and grease	mg/L	every 6 days	5	10	25	32
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2
total suspended solids	mg/L	every 6 days	5	110	158	200

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the May monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## April Pollution Monitoring Summary



### EPL 378

Summary period: 01-04-2025 to 30-04-2025  
Date obtained: 07-05-2025  
Date published: 15-05-2025

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	37	yes
total suspended solids	mg/L	monthly	290	206	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	322
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	60.8
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	65
nonylphenol ethoxylate	ug/L	monthly	1	-	-	46
oil and grease	mg/L	every 6 days	5	20	37	44
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	8
total suspended solids	mg/L	every 6 days	5	140	196	240

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the April monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## March Pollution Monitoring Summary



### EPL 378

Summary period: 01-03-2025 to 31-03-2025  
 Date obtained: 04-04-2025  
 Date published: 15-04-2025

**Licensee:** Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	40	yes
total suspended solids	mg/L	monthly	290	233	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	511
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	104
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	50
nonylphenol ethoxylate	ug/L	monthly	1	-	-	115
oil and grease	mg/L	every 6 days	5	23	39	54
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	3.6
total suspended solids	mg/L	every 6 days	5	180	222	260

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the March monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## February Pollution Monitoring Summary



### EPL 378

Summary period: 01-02-2025 to 28-02-2025  
 Date obtained: 07-03-2025  
 Date published: 19-03-2025

**Licensee:** Sydney Water Corporation  
 PO Box 399  
 PARRAMATTA NSW 2124

**Table 1: 3 Day Geometric Mean data**

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	42	yes
total suspended solids	mg/L	monthly	290	213	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

**Table 2: Routine monitoring data**

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	465
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	125
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	24
oil and grease	mg/L	every 6 days	5	33	44	59
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	5.8
total suspended solids	mg/L	every 6 days	5	180	228	280

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the February monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## January Pollution Monitoring Summary



### EPL 378

Summary period: 01-01-2025 to 31-01-2025  
Date obtained: 09-02-2025  
Date published: 21-02-2025

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	44	yes
total suspended solids	mg/L	monthly	290	206	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	443
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	144
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	31
nonylphenol ethoxylate	ug/L	monthly	1	-	-	73
oil and grease	mg/L	every 6 days	5	21	33	45
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.8
total suspended solids	mg/L	every 6 days	5	150	174	220

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the January monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## December Pollution Monitoring Summary



### EPL 378

Summary period: 01-12-2024 to 31-12-2024  
Date obtained: 06-01-2025  
Date published: 15-01-2025

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	48	yes
total suspended solids	mg/L	monthly	290	236	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	452
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	128
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	73
nonylphenol ethoxylate	ug/L	monthly	1	-	-	39
oil and grease	mg/L	every 6 days	5	37	46	51
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.3
total suspended solids	mg/L	every 6 days	5	180	218	260

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the December monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## November Pollution Monitoring Summary



### EPL 378

Summary period: 01-11-2024 to 30-11-2024  
Date obtained: 09-12-2024  
Date published: 13-12-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	52	yes
total suspended solids	mg/L	monthly	290	207	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	348
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	113
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	300
nonylphenol ethoxylate	ug/L	monthly	1	-	-	73
oil and grease	mg/L	every 6 days	5	48	49	51
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	10.2
total suspended solids	mg/L	every 6 days	5	180	218	250

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the November monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).



# North Head Water Resource Recovery Facility

## October Pollution Monitoring Summary



### EPL 378

Summary period: 01-10-2024 to 31-10-2024  
Date obtained: 06-11-2024  
Date published: 15-11-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	54	yes
total suspended solids	mg/L	monthly	290	199	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	267
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	73.4
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	52
nonylphenol ethoxylate	ug/L	monthly	1	-	-	55
oil and grease	mg/L	every 6 days	5	46	51	53
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	1.8
total suspended solids	mg/L	every 6 days	5	180	214	230

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the October monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## September Pollution Monitoring Summary



### EPL 378

Summary period: 01-09-2024 to 30-09-2024  
Date obtained: 10-10-2024  
Date published: 23-10-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	51	yes
total suspended solids	mg/L	monthly	290	179	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	462
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	124
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	89
nonylphenol ethoxylate	ug/L	monthly	1	-	-	97
oil and grease	mg/L	every 6 days	5	49	53	58
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.4
total suspended solids	mg/L	every 6 days	5	190	208	250

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the September monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## August Pollution Monitoring Summary



### EPL 378

Summary period: 01-08-2024 to 31-08-2024  
Date obtained: 11-09-2024  
Date published: 13-09-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	45	yes
total suspended solids	mg/L	monthly	290	200	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	560
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	122
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	88
oil and grease	mg/L	every 6 days	6	42	46	49
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.4
total suspended solids	mg/L	every 6 days	6	160	185	220

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the August monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).

# North Head Water Resource Recovery Facility

## July Pollution Monitoring Summary



### EPL 378

Summary period: 01-07-2024 to 31-07-2024  
Date obtained: 08-08-2024  
Date published: 16-08-2024

**Licensee:** Sydney Water Corporation  
PO Box 399  
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
oil and grease	mg/L	monthly	85	32	yes
total suspended solids	mg/L	monthly	290	155	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 8 Site code NH0008		Point description: In effluent channel downstream of the dropshaft				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	402
chlorpyrifos	ug/L	monthly	1	-	-	<0.05
copper	ug/L	monthly	1	-	-	75.7
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
nonylphenol ethoxylate	ug/L	monthly	1	-	-	62
oil and grease	mg/L	every 6 days	5	30	37	45
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	2.9
total suspended solids	mg/L	every 6 days	5	130	154	170

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

As per clause M2.4 under EPL 378, collection of samples from EPA Point 9 is required when sewage or effluent is discharged from EPA Point 6. There was no discharge from EPA Point 6 during the July monitoring period.

Effluent quality monitoring results obtained from EPA Point 8 are used to indicate the quality of water discharged at EPA Point 5 (deep water ocean outfall).