# Picton Wastewater Treatment Plant June Pollution Monitoring Summary



### EPL 10555

Summary period: 01-06-2020 to 30-06-2020 Date obtained: 08-07-2020 Date published: 20-07-2020 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

#### Table 1: Routine monitoring data

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	14	<2	<2	2	
faecal coliforms	CFU/100mL	on bypass	14	21	127	390	
nitrogen (ammonia)	mg/L	on bypass	14	<0.1	0.17	0.2	
nitrogen (total)	mg/L	on bypass	14	4.25	4.82	5	
phosphorus (total)	mg/L	on bypass	14	0.02	0.03	0.07	
total suspended solids	mg/L	on bypass	14	<2	<2	<2	

Average and percentile limits are only applied annually for routine monitoring data

No samples collected at EPA Points 11 and 13 as the irrigation system was not operating during the June monitoring period.

# Picton Wastewater Treatment Plant May Pollution Monitoring Summary<sup>-</sup>



## EPL 10555<sup>-</sup>

Summary period: 01-05-2020 to 31-05-2020Á Date obtained: 05-06-2020Á Date published: 1Ï -06-2020Á Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	13	<2	<2	<2	
faecal coliforms	CFU/100mL	on bypass	13	14	52	190	
nitrogen (ammonia)	mg/L	on bypass	13	<0.1	<0.1	0.1	
nitrogen (total)	mg/L	on bypass	13	4.38	4.63	4.81	
phosphorus (total)	mg/L	on bypass	13	0.02	0.03	0.03	
total suspended solids	mg/L	on bypass	13	<2	<2	2	

Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	2	<2	3	6		
faecal coliforms	CFU/100mL	every 6 days when irrigating	2	10	220	430		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	2	0.7	0.74	0.77		
nitrogen (total)	mg/L	every 6 days when irrigating	2	4.3	4.32	4.34		
рН	pH Units	every 6 days when irrigating	2	7.8	7.84	7.87		
phosphorus (total)	mg/L	every 6 days when irrigating	2	0.44	0.47	0.49		
total suspended solids	mg/L	every 6 days when irrigating	2	<2	<2	2		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	2	<2	<2	<2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	2	11	24	36		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	2	0.07	0.09	0.1		
nitrogen (total)	mg/L	every 6 days when irrigating	2	4.6	4.63	4.66		
рН	pH Units	every 6 days when irrigating	2	7.67	7.71	7.74		
phosphorus (total)	mg/L	every 6 days when irrigating	2	0.02	0.02	0.03		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
total suspended solids	mg/L	every 6 days when irrigating	2	<2	<2	<2	

# Picton Wastewater Treatment Plant April Pollution Monitoring Summary



## EPL 10555

Summary period: 01-04-2020 to 30-04-2020 Date obtained: 07-05-2020 Date published: 15-05-2020 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	4	<2	<2	<2	
faecal coliforms	CFU/100mL	on bypass	4	56	116	220	
nitrogen (ammonia)	mg/L	on bypass	4	<0.1	0.13	0.2	
nitrogen (total)	mg/L	on bypass	4	4.15	4.63	4.97	
phosphorus (total)	mg/L	on bypass	4	0.03	0.04	0.06	
total suspended solids	mg/L	on bypass	4	<2	2	4	

Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	1	-	_	<2	
faecal coliforms	CFU/100mL	every 6 days when irrigating	1	-	-	16	
nitrogen (ammonia)	mg/L	every 6 days when irrigating	1	-	_	1.16	
nitrogen (total)	mg/L	every 6 days when irrigating	1	-	-	4.42	
рН	pH Units	every 6 days when irrigating	1	_	-	7.54	
phosphorus (total)	mg/L	every 6 days when irrigating	1	_	-	0.59	
total suspended solids	mg/L	every 6 days when irrigating	1	-	-	<2	

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	2	<2	<2	<2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	2	54	75	96		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	2	0.07	0.08	0.08		
nitrogen (total)	mg/L	every 6 days when irrigating	2	4.03	4.41	4.79		
рН	pH Units	every 6 days when irrigating	2	7.46	7.52	7.57		
phosphorus (total)	mg/L	every 6 days when irrigating	2	0.03	0.03	0.03		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
total suspended solids	mg/L	every 6 days when irrigating	2	<2	<2	3	

# Picton Wastewater Treatment Plant March Pollution Monitoring Summary



### EPL 10555

Summary period: 01-03-2020 to 31-03-2020 Date obtained: 04-04-2020 Date published: 15-04-2020 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

#### Table 1: Routine monitoring data

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	6	<2	<2	2	
faecal coliforms	CFU/100mL	on bypass	6	49	359	1,300	
nitrogen (ammonia)	mg/L	on bypass	6	0.1	0.28	0.4	
nitrogen (total)	mg/L	on bypass	6	4.19	4.47	4.95	
phosphorus (total)	mg/L	on bypass	6	0.03	0.07	0.2	
total suspended solids	mg/L	on bypass	6	2	4	7	

Average and percentile limits are only applied annually for routine monitoring data.

No samples collected at EPA Points 11 and 13 as the irrigation system was not operating during the March monitoring period

# Picton Wastewater Treatment Plant February Pollution Monitoring Summary



## EPL 10555

Summary period: 01-02-2020 to 29-02-2020 Date obtained: 24-03-2020 Date published: 27-03-2020 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

#### Table 1: Routine monitoring data

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	11	<2	<2	3	
faecal coliforms	CFU/100mL	on bypass	11	250	703	2,400	
nitrogen (ammonia)	mg/L	on bypass	11	0.1	0.76	1.3	
nitrogen (total)	mg/L	on bypass	11	3.44	4.34	5.36	
oil and grease	mg/L	on bypass	2	<5	<5	<5	
phosphorus (total)	mg/L	on bypass	11	0.16	0.18	0.21	
total suspended solids	mg/L	on bypass	11	9	14	22	

Average and percentile limits are only applied annually for routine monitoring data.

No samples collected at EPA Points 11 and 13 as the irrigation system was not operating during the February monitoring period

# Picton Wastewater Treatment Plant January Pollution Monitoring Summary



## EPL 10555

Summary period: 01-01-2020 to 31-01-2020 Date obtained: 06-02-2020 Date published: 14-02-2020 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

### Table 1: Routine monitoring data

EPA Point 11 Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	4	<2	3	5		
faecal coliforms	CFU/100mL	every 6 days when irrigating	4	5	28	89		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	4	0.03	0.1	0.24		
nitrogen (total)	mg/L	every 6 days when irrigating	4	4.59	5.11	5.52		
рН	pH Units	every 6 days when irrigating	4	9.03	9.57	9.97		
phosphorus (total)	mg/L	every 6 days when irrigating	4	0.67	0.87	1.06		
total suspended solids	mg/L	every 6 days when irrigating	4	<2	7	15		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	4	<2	3	4		
faecal coliforms	CFU/100mL	every 6 days when irrigating	4	91	303	560		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	4	0.01	0.06	0.17		
nitrogen (total)	mg/L	every 6 days when irrigating	4	1.59	1.95	2.79		
рН	pH Units	every 6 days when irrigating	4	9.03	9.38	9.6		
phosphorus (total)	mg/L	every 6 days when irrigating	4	0.09	0.16	0.22		
total suspended solids	mg/L	every 6 days when irrigating	4	5	9	11		

Average and percentile limits are only applied annually for routine monitoring data

# Picton Wastewater Treatment Plant December Pollution Monitoring Summary



### EPL 10555

Summary period: 01-12-2019 to 31-12-2019 Date obtained: 27-12-2019 Date published: 10-01-2020 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

#### Table 1: Routine monitoring data

EPA Point 11 Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	2	<2	<2	<2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	2	14	18	22		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	2	0.02	0.04	0.06		
nitrogen (total)	mg/L	every 6 days when irrigating	2	5.44	5.51	5.58		
рН	pH Units	every 6 days when irrigating	2	9.39	9.6	9.8		
phosphorus (total)	mg/L	every 6 days when irrigating	2	1.08	1.25	1.42		
total suspended solids	mg/L	every 6 days when irrigating	2	4	5	5		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	2	<2	<2	2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	2	25	44	62		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	2	0.07	0.16	0.24		
nitrogen (total)	mg/L	every 6 days when irrigating	2	2.41	2.53	2.64		
рН	pH Units	every 6 days when irrigating	2	8.44	8.76	9.07		
phosphorus (total)	mg/L	every 6 days when irrigating	2	0.04	0.04	0.05		
total suspended solids	mg/L	every 6 days when irrigating	2	<2	3	5		

Average and percentile limits are only applied annually for routine monitoring data

## Picton Wastewater Treatment Plant November Pollution Monitoring Summary



### EPL 10555

Summary period: 01-11-2019 to 30-11-2019 Date obtained: 27-11-2019 Date published: 09-12-2019

Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

#### Table 1: Routine monitoring data

EPA Point 11 Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	4	<2	<2	3		
faecal coliforms	CFU/100mL	every 6 days when irrigating	4	32	45	58		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	4	0.02	0.04	0.05		
nitrogen (total)	mg/L	every 6 days when irrigating	4	4.36	4.57	4.75		
рН	pH Units	every 6 days when irrigating	4	9.37	9.48	9.61		
phosphorus (total)	mg/L	every 6 days when irrigating	4	0.53	0.99	1.42		
total suspended solids	mg/L	every 6 days when irrigating	4	2	4	6		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	4	<2	<2	<2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	4	14	89	210		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	4	0.11	0.15	0.22		
nitrogen (total)	mg/L	every 6 days when irrigating	4	3.21	3.5	3.88		
рН	pH Units	every 6 days when irrigating	4	8.28	8.46	8.81		
phosphorus (total)	mg/L	every 6 days when irrigating	4	0.04	0.05	0.07		
total suspended solids	mg/L	every 6 days when irrigating	4	<2	3	4		

Average and percentile limits are only applied annually for routine monitoring data

No samples collected from EPA Point 1 during the November period.

# Picton Wastewater Treatment Plant October Pollution Monitoring Summary



## EPL 10555

Summary period: 01-10-2019 to 31-10-2019 Date obtained: 29-10-2019 Date published: 12-11-2019 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	8	<2	<2	<2	
faecal coliforms	CFU/100mL	on bypass	8	13	40	85	
nitrogen (ammonia)	mg/L	on bypass	8	<0.1	<0.1	0.1	
nitrogen (total)	mg/L	on bypass	8	3.99	4.18	4.43	
phosphorus (total)	mg/L	on bypass	8	0.02	0.03	0.04	
total suspended solids	mg/L	on bypass	8	<2	<2	<2	

EPA Point 11 Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	3	<2	<2	<2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	3	7	12	21		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	3	0.03	0.04	0.05		
nitrogen (total)	mg/L	every 6 days when irrigating	3	4.28	4.38	4.53		
рН	pH Units	every 6 days when irrigating	3	9.19	9.41	9.56		
phosphorus (total)	mg/L	every 6 days when irrigating	3	0.21	0.23	0.26		
total suspended solids	mg/L	every 6 days when irrigating	3	<2	<2	3		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	3	<2	<2	<2		
faecal coliforms	CFU/100mL	every 6 days when irrigating	3	19	56	110		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	3	0.1	0.17	0.21		
nitrogen (total)	mg/L	every 6 days when irrigating	3	4.16	4.23	4.3		
рН	pH Units	every 6 days when irrigating	3	7.74	7.85	8.02		
phosphorus (total)	mg/L	every 6 days when irrigating	3	0.03	0.05	0.07		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
total suspended solids	mg/L	every 6 days when irrigating	3	<2	<2	<2	

# Picton Wastewater Treatment Plant September Pollution Monitoring Summary



## EPL 10555

Summary period: 01-09-2019 to 30-09-2019 Date obtained: 01-10-2019 Date published: 15-10-2019 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	on bypass	4	<2	<2	<2	
faecal coliforms	CFU/100mL	on bypass	4	7	44	89	
nitrogen (ammonia)	mg/L	on bypass	4	<0.1	<0.1	<0.1	
nitrogen (total)	mg/L	on bypass	4	3.99	4.16	4.39	
phosphorus (total)	mg/L	on bypass	4	0.02	0.03	0.03	
total suspended solids	mg/L	on bypass	4	<2	<2	<2	

EPA Point 11 Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result		
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	1	-	_	3		
faecal coliforms	CFU/100mL	every 6 days when irrigating	1	-	_	35		
nitrogen (ammonia)	mg/L	every 6 days when irrigating	1	-	-	0.06		
nitrogen (total)	mg/L	every 6 days when irrigating	1	-	-	4.45		
рН	pH Units	every 6 days when irrigating	1	_	-	8.43		
phosphorus (total)	mg/L	every 6 days when irrigating	1	-	-	0.33		
total suspended solids	mg/L	every 6 days when irrigating	1	-	-	2		

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	1	_	_	<2	
faecal coliforms	CFU/100mL	every 6 days when irrigating	1	-	_	20	
nitrogen (ammonia)	mg/L	every 6 days when irrigating	1	-	-	0.04	
nitrogen (total)	mg/L	every 6 days when irrigating	1	_	_	4.79	
рН	pH Units	every 6 days when irrigating	1	_	_	7.89	
phosphorus (total)	mg/L	every 6 days when irrigating	1	_	-	0.05	

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
total suspended solids	mg/L	every 6 days when irrigating	1	-	-	<2

# Picton Wastewater Treatment Plant August Pollution Monitoring Summary



## EPL 10555

Summary period: 01-08-2019 to 31-08-2019 Date obtained: 06-09-2019 Date published: 16-09-2019 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

### Table 1: Routine monitoring data

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
carbonaceous biochemical oxygen demand	mg/L	on bypass	11	<2	<2	<2
faecal coliforms	CFU/100mL	on bypass	11	12	32	71
nitrogen (ammonia)	mg/L	on bypass	11	<0.1	<0.1	0.3
nitrogen (total)	mg/L	on bypass	11	4.42	4.64	4.79
phosphorus (total)	mg/L	on bypass	11	0.02	0.02	0.03
total suspended solids	mg/L	on bypass	11	<2	<2	<2

EPA Point 11 Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	1	-	-	<2
faecal coliforms	CFU/100mL	every 6 days when irrigating	1	-	-	6
nitrogen (ammonia)	mg/L	every 6 days when irrigating	1	-	_	0.02
nitrogen (total)	mg/L	every 6 days when irrigating	1	-	-	4.81
рН	pH Units	every 6 days when irrigating	1	-	-	8.06
phosphorus (total)	mg/L	every 6 days when irrigating	1	_	-	0.35
total suspended solids	mg/L	every 6 days when irrigating	1	-	-	3

No samples collected at EPA Point 13 as the irrigation system was not operating during the August monitoring period.

# Picton Wastewater Treatment Plant July Pollution Monitoring Summary



## EPL 10555

Summary period: 01-07-2019 to 31-07-2019 Date obtained: 31-07-2019 Date published: 08-08-2019 Licensee: Sydney Water Corporation PO Box 399 PARRAMATTA NSW 2124

EPA Point 1 Site code Pl0001	Point description: Outlet of the effluent buffer tank at the western dam					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
carbonaceous biochemical oxygen demand	mg/L	on bypass	14	<2	<2	<2
faecal coliforms	CFU/100mL	on bypass	14	16	47	76
nitrogen (ammonia)	mg/L	on bypass	14	<0.1	<0.1	0.1
nitrogen (total)	mg/L	on bypass	14	4.67	4.86	4.97
phosphorus (total)	mg/L	on bypass	14	0.02	0.03	0.05
total suspended solids	mg/L	on bypass	14	<2	<2	4

Site code Pl0011	Point description: Outlet of the effluent irrigation eastern dam						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result	
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	2	<2	<2	2	
faecal coliforms	CFU/100mL	every 6 days when irrigating	2	6	73	140	
nitrogen (ammonia)	mg/L	every 6 days when irrigating	2	0.01	0.04	0.06	
nitrogen (total)	mg/L	every 6 days when irrigating	2	4.23	4.32	4.4	
рН	pH Units	every 6 days when irrigating	2	7.97	8.04	8.1	
phosphorus (total)	mg/L	every 6 days when irrigating	2	0.49	0.49	0.49	
total suspended solids	mg/L	every 6 days when irrigating	2	<2	<2	3	

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
carbonaceous biochemical oxygen demand	mg/L	every 6 days when irrigating	1	-	-	<2
faecal coliforms	CFU/100mL	every 6 days when irrigating	1	-	-	42
nitrogen (ammonia)	mg/L	every 6 days when irrigating	1	-	-	0.06
nitrogen (total)	mg/L	every 6 days when irrigating	1	-	-	4.65
рН	pH Units	every 6 days when irrigating	1	-	_	7.65
phosphorus (total)	mg/L	every 6 days when irrigating	1	-	-	0.04

EPA Point 13 Site code Pl0013	Point description: Outlet of the effluent irrigation western dam					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
total suspended solids	mg/L	every 6 days when irrigating	1	-	-	<2