

Riverstone Water Resource Recovery Facility

July Pollution Monitoring Summary



EPL 1796

Summary period: 01-07-2026 to 31-07-2026

Date obtained: 07-08-2026

Date published: 19-08-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean and 100 percentile data

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank					
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM actual	100 percentile limit	100 percentile actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	-	-	yes
total suspended solids	mg/L	monthly	10	<2	-	-	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 3 Site code RS0003		Point description: Downstream of the weir in the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	107
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	0.7
iron	ug/L	monthly	1	-	-	30
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.61	1.51
nitrogen (total)	mg/L	every 6 days	5	1.91	2.75	4.22
phosphorus	mg/L	every 6 days	5	0.014	0.021	0.026
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	14

EPA Point 4 Site code RS0004		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Points 3 and 4 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).