

Warriewood Water Resource Recovery Facility

August Pollution Monitoring Summary



EPL 1784

Summary period: 01-08-2025 to 31-08-2025
 Date obtained: 02-09-2025
 Date published: 12-09-2025

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits	
total suspended solids	mg/L	monthly	80	40	yes	

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	42
copper	ug/L	monthly	1	-	-	7.9
cyanide	ug/L	monthly	1	-	-	6
faecal coliforms	CFU/100mL	every 6 days	5	56	47,481	130,000
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	87
total suspended solids	mg/L	every 6 days	5	10	48	88

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

Warriewood Water Resource Recovery Facility

July Pollution Monitoring Summary



EPL 1784

Summary period: 01-07-2025 to 31-07-2025
Date obtained: 31-07-2025
Date published: 14-08-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WW0005		Point description: Outfall pipeline on the plant's eastern boundary				
pollutant		unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids		mg/L	monthly	80	6	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WW0005	Point description: Outfall pipeline on the plant's eastern boundary					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	16
copper	ug/L	monthly	1	-	-	6.2
cyanide	ug/L	monthly	1	-	-	12
faecal coliforms	CFU/100mL	every 6 days	5	6	16	29
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	81.4
total suspended solids	mg/L	every 6 days	5	6	7	11

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).