

West Camden Water Resource Recovery Facility

March Pollution Monitoring Summary



EPL 1675

Summary period: 01-03-2025 to 31-03-2025
Date obtained: 07-04-2025
Date published: 15-04-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	3	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	33
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
chromium	ug/L	monthly	1	-	-	<0.2
copper	ug/L	monthly	1	-	-	1.9
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	<1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	36
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.01	0.02
nitrogen (total)	mg/L	every 6 days	5	3.47	4.11	4.91
phosphorus (total)	mg/L	every 6 days	5	0.05	0.13	0.22
total suspended solids	mg/L	every 6 days	5	<2	<2	4
zinc	ug/L	monthly	1	-	-	25

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

February Pollution Monitoring Summary



EPL 1675

Summary period: 01-02-2025 to 28-02-2025

Date obtained: 10-03-2025

Date published: 15-03-2025

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	54
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
chromium	ug/L	monthly	1	-	-	<0.2
cobalt	ug/L	bi-annually	1	-	-	0.7
copper	ug/L	monthly	1	-	-	0.6
cyanide	ug/L	bi-annually	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	3	4
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	27
nickel	ug/L	bi-annually	1	-	-	5.2
nitrogen (ammonia)	mg/L	every 6 days	5	0.01	0.05	0.11
nitrogen (total)	mg/L	every 6 days	5	2.3	4.63	8.39
phosphorus (total)	mg/L	every 6 days	5	0.02	0.05	0.11
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	26

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

January Pollution Monitoring Summary



EPL 1675

Summary period: 01-01-2025 to 31-01-2025
 Date obtained: 04-02-2025
 Date published: 14-02-2025

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005	Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005	Point description: At the outlet of the chlorine contact tank					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	65
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	8.1
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	0.08
chromium	ug/L	monthly	1	-	-	<0.2
copper	ug/L	monthly	1	-	-	0.6
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	3
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	26
nitrogen (ammonia)	mg/L	every 6 days	5	0.02	0.9	3.85
nitrogen (total)	mg/L	every 6 days	5	7.84	10.32	14.3
phosphorus (total)	mg/L	every 6 days	5	0.02	0.03	0.05
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	17

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

December Pollution Monitoring Summary



EPL 1675

Summary period: 01-12-2024 to 31-12-2024
Date obtained: 07-01-2025
Date published: 15-01-2025

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	87
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
chromium	ug/L	monthly	1	-	-	0.3
copper	ug/L	monthly	1	-	-	0.7
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	5
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	39
nitrogen (ammonia)	mg/L	every 6 days	5	0.19	0.98	2.98
nitrogen (total)	mg/L	every 6 days	5	5.54	7.34	9.38
phosphorus (total)	mg/L	every 6 days	5	0.02	0.02	0.03
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	25

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

November Pollution Monitoring Summary



EPL 1675

Summary period: 01-11-2024 to 30-11-2024
Date obtained: 10-12-2024
Date published: 13-12-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	40
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
cadmium	ug/L	monthly	1	-	-	<0.1
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
chromium	ug/L	monthly	1	-	-	<0.2
copper	ug/L	monthly	1	-	-	<0.5
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	4	10	16
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	125
nitrogen (ammonia)	mg/L	every 6 days	5	0.65	1.05	1.46
nitrogen (total)	mg/L	every 6 days	5	4.81	5.67	6.59
phosphorus (total)	mg/L	every 6 days	5	0.03	0.03	0.05
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	12

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

October Pollution Monitoring Summary



EPL 1675

Summary period: 01-10-2024 to 31-10-2024
Date obtained: 06-11-2024
Date published: 15-11-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	86
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
copper	ug/L	monthly	1	-	-	0.7
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	54
nitrogen (ammonia)	mg/L	every 6 days	5	0.42	0.82	1.39
nitrogen (total)	mg/L	every 6 days	5	5.22	7.08	8.41
phosphorus (total)	mg/L	every 6 days	5	0.03	0.03	0.04
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	14

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

September Pollution Monitoring Summary



EPL 1675

Summary period: 01-09-2024 to 30-09-2024
Date obtained: 09-10-2024
Date published: 23-10-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005	Point description: At the outlet of the chlorine contact tank					
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	138
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
copper	ug/L	monthly	1	-	-	0.6
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	4	11
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	118
nitrogen (ammonia)	mg/L	every 6 days	5	0.18	0.73	1.35
nitrogen (total)	mg/L	every 6 days	5	7.69	8.87	11.2
phosphorus (total)	mg/L	every 6 days	5	0.02	0.03	0.04
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	19

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

August Pollution Monitoring Summary



EPL 1675

Summary period: 01-08-2024 to 31-08-2024
Date obtained: 12-09-2024
Date published: 26-09-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	92
biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	6	<0.04	<0.04	<0.04
cobalt	ug/L	bi-annually	1	-	-	0.4
copper	ug/L	monthly	1	-	-	0.7
cyanide	ug/L	bi-annually	1	-	-	<5
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	6	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	44
nickel	ug/L	bi-annually	1	-	-	2
nitrogen (ammonia)	mg/L	every 6 days	5	0.52	1.27	1.97
nitrogen (total)	mg/L	every 6 days	5	7.76	9.18	10.9
phosphorus (total)	mg/L	every 6 days	5	0.03	0.05	0.10
total suspended solids	mg/L	every 6 days	5	<2	<2	<2
zinc	ug/L	monthly	1	-	-	17

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).

West Camden Water Resource Recovery Facility

July Pollution Monitoring Summary



EPL 1675

Summary period: 01-07-2024 to 31-07-2024
Date obtained: 18-08-2024
Date published: 27-08-2024

Licensee: Sydney Water Corporation
PO Box 399
PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
biochemical oxygen demand	mg/L	monthly	30	<2	yes
total suspended solids	mg/L	monthly	30	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	161
biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100
chlorine (total residual)	mg/L	every 6 days	5	<0.04	<0.04	<0.04
copper	ug/L	monthly	1	-	-	0.8
diazinon	ug/L	monthly	1	-	-	<0.1
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
iron	ug/L	monthly	1	-	-	44
nitrogen (ammonia)	mg/L	every 6 days	6	0.75	2.04	4.29
nitrogen (total)	mg/L	every 6 days	6	7.5	12.9	18.0
phosphorus (total)	mg/L	every 6 days	6	0.05	0.12	0.23
total suspended solids	mg/L	every 6 days	6	<2	<2	<2
zinc	ug/L	monthly	1	-	-	22

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).