Wollongong Water Resource Recovery Facility July Pollution Monitoring Summary

EPL 218

Summary period: 01-07-2025 to 31-07-2025

Date obtained: 05-08-2025

Date published: 15-08-2025

Sydney **WAT ₹R**

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 5 Site code WO0005	Point description: At the inlet to the effluent pumping station							
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits			
total suspended solids	mg/L	monthly	50	<2	yes			

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 5 Site code WO0005	Point descrip	Point description: At the inlet to the effluent pumping station							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result			
aluminium	ug/L	monthly	1	-	_	14			
biochemical oxygen demand	mg/L	every 6 days	5	3	5	9			
copper	ug/L	monthly	1	-	_	4.2			
diazinon	ug/L	monthly	1	-	_	<0.1			
hydrogen sulphide (unionised)	ug/L	monthly	1	-	_	<30			
total suspended solids	mg/L	every 6 days	5	<2	4	16			

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Effluent quality monitoring results obtained from EPA Point 5 are used to indicate the quality of water discharged at EPA Point 1 (discharge to waters).