

Cronulla Wastewater Treatment Plant

2025-26 Pollution monitoring yearly limit summaries



EPL 1728

Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
biochemical oxygen demand	mg/L	every 6 days	61	<2	31	15	6	yes
oil and grease	mg/L	every 6 days	61	<5	9	5	<5	yes
total suspended solids	mg/L	every 6 days	61	<2	31	10	<2	yes

Cronulla Wastewater Treatment Plant

2025-26 Pollution monitoring yearly limit summaries



EPL 1728

Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	13	40	383	30	yes
biochemical oxygen demand	mg/L	every 6 days	61	<2	31	20	13	yes
chlorpyrifos	ug/L	monthly	12	<0.05	<0.05	1	<0.05	yes
copper	ug/L	monthly	12	3.2	7.6	500	6.2	yes
cyanide	ug/L	monthly	12	<5	<5	10	<5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	2	<0.1	yes
nitrogen (ammonia)	mg/L	monthly	12	3.4	18.4	52	18.3	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	8	11	7	yes
oil and grease	mg/L	every 6 days	61	<5	9	8	<5	yes
total suspended solids	mg/L	every 6 days	61	<2	31	15	3	yes
zinc	ug/L	monthly	12	24	38	100	36	yes

Cronulla Wastewater Treatment Plant

2025-26 Pollution monitoring yearly limit summaries



EPL 1728

Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 3 Site code CR0003		Point description: Inlet to the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	13	40	100	24	yes
chlorpyrifos	ug/L	monthly	12	<0.05	<0.05	0.09	<0.05	yes
copper	ug/L	monthly	12	3.2	7.6	50	4.6	yes
cyanide	ug/L	monthly	12	<5	<5	5	<5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.2	<0.1	yes
nitrogen (ammonia)	mg/L	monthly	12	3.4	18.4	31	11.4	yes
nonylphenol ethoxylate	ug/L	monthly	12	<5	8	8	<5	yes
zinc	ug/L	monthly	12	24	38	55	29	yes

50 percentile yearly summary								
EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	14,000	200	13	yes

Cronulla Wastewater Treatment Plant

2025-26 Pollution monitoring yearly limit summaries



EPL 1728

Summary period: 01-07-2025 to 30-06-2026

Date published: 20-07-2026

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	70	<30	yes

90 percentile yearly summary								
EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	77.8	100	0.19	90.3	yes

Average yearly summary								
EPA Point 17 Site code CR0017		Point description: Outlet of the UV chamber						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	38	<30	yes
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	12	77.8	100	1.53	97.3	yes